


CONCRETE SLAB ON GRADE SCHEDULE

S1
 150 CONCRETE SLAB ON MINIMUM 150 WELL
 COMPACTED GRANULAR BASE, MINIMUM 300 WELL
 COMPACTED GRANULAR SUB-BASE R/W 10M @ 400 O/C
 EA. WAY TOP

S2
 150 CONCRETE SLAB ON MINIMUM 150 WELL
 COMPACTED GRANULAR BASE, MINIMUM 300 WELL
 COMPACTED GRANULAR SUB-BASE R/W 15M L-
 DOWELS @ 300 O/C TOP, 10M TRANSVERSE @ 400 O/C.
 PROVIDE MINIMUM 150mm VOID FORM 1220 FROM
 FACE OF GRADE BEAM AT FULL WIDTH OF MAN-DOOR
 OPENING.

NOTE:
 ADDITIONAL BACKFILL IS REQUIRED AROUND THE
 SHED PERIMETER TO TIE INTO EXISTING ADJACENT
 GRADES. REFER TO ARCHITECTURAL SITE PLAN FOR
 EXTENT AND TYPE OF BACKFILL FOR FINISH GRADE
 CONDITION.



1 MAIN FLOOR FRAMING PLAN
 S201 1 : 75

