



851-2017 ADDENDUM 2

SASKATCHEWAN AVENUE AT STURGEON CREEK BRIDGE CONSTRUCTION

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: October 19, 2017
BY: D. Mitchell
TELEPHONE NO. 204 954-6880

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART A – BID SUBMISSION

Replace: 851-2017 Addendum 1 – Bid Submission with 851-2017 Addendum 2- Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

- Form B(R1): Revise Description Item B.21 i)
- Form B(R1): Revise Quantity Item B.27 i)
- Form B(R1): Revise Quantity Item B.28 i)
- Form B(R1): Add Item C.4 i)
- Form B(R1): Revise Quantity Item C.4 ii)
- Form B(R1): Revise Quantity Item C.5 i)
- Form B(R1): Revise Quantity Item C.6 i)
- Form B(R1): Revise Quantity Item C.8 i) a)
- Form B(R1): Revise Quantity Item C.9 i)

PART E – SPECIFICATIONS

- Revise: E17.5.3(e) to read: Pipe piles shall be zinc metalized and coated for a length of 5m, so that coating is for the top half of the pile, which will be exposed. Zinc metalizing shall be 99.9% zinc to a minimum thickness of 4 mils.
- Add: E17.7.4(c): All Abutment Steel "H" piles and Embankment Steel "H" piles shall be fitted with hard bite point driving shoes, and all pipe piles shall be fitted with cutting shoes.
- Revise: E19.5.14(a) to read: Structural inserts shall be Dayton Superior Type F-57 expanded coil ferrule insert, galvanized. Insert to come as a unit with 25mm diameter, 50mm long, A307 bolts, with lock washers, galvanized. Galvanizing to be in accordance with CSA G164, to a net retention of 600 g/m².