



958-2017 ADDENDUM 2

REQUEST FOR PROPOSAL FOR PROFESSIONAL CONSULTING SERVICES FOR PROVISION OF DETAILED DESIGN AND CONTRACT ADMINISTRATION SERVICES FOR THE HAWTHORNE WASTEWATER PUMPING STATION UPGRADES

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE REQUEST FOR PROPOSAL

ISSUED: November 21, 2017
BY: Doug Berg, C.E.T.
TELEPHONE NO. 204 - 986-4452

THIS ADDENDUM SHALL BE INCORPORATED INTO THE REQUEST FOR PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: Ar20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Proposal may render your Proposal non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D3.5 (a) (iii) to read: The Consultant will be required to conduct a hydraulic review of the Station suction and discharge piping to determine the required capacity and HP rating of the pumps and motors and if they can be increased in size to reduce pump cycle run time and without overwhelming the downstream interceptor sewer on Newton Avenue. The Consultant shall also take into consideration the effect of the incoming flow from the Linden Wastewater Pumping Station and forcemain that connects to the same forcemain river crossing location connecting to the Newton Avenue interceptor.

Add: D4.3 (d) The City of Winnipeg; Water and Waste Department – WWD CAD-GIS Drawing Standards

http://winnipeg.ca/waterandwaste/dept/cad_gis.stm