



1-2018 ADDENDUM 1

LOCAL STREET RENEWAL PROGRAM: AGNES ARNOLD PLACE, BANNERMAN AVENUE AND VARIOUS OTHER LOCATIONS

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: March 8, 2018
BY: Cory Humbert
TELEPHONE NO. 204 226-2303

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART A – BID SUBMISSION

Replace: 1-2018 Bid Submission with 1-2018 Addendum 1 - Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

Form B(R1): Change Description for C.20 i) from “SD-024, 1800 mm deep” to “SD-024, 1200 mm deep”

Form B(R1): Revise Approximate Quantities for Item Numbers J.1 to J.7, and J.9

Page numbering on some forms may be changed as a result.

PART E – SPECIFICATIONS

Revise: E17.8.2 to read: Revisions and updates to the Manitoba Hydro 66kV and Below Standards are issued periodically and the latest issued version of the Standard will apply. For the convenience of the Contractor for bidding purposes, excerpts of the Manitoba Hydro 66kV and Below Standards have been included as Appendix B.