



1077-2018 ADDENDUM 3

FIRE PROTECTION UPGRADES AT 552 PLINGUET

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: February 20, 2019
BY: Rob Carroll
TELEPHONE NO. 204 986-8409

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Add: E1.4 The following drawings are included for reference:

<u>Drawing No.</u>	<u>Drawing Name/Title</u>
D-6738	Redevelopment of Plinguet Site – New Building - Floor Plan
D-6746	Redevelopment of Plinguet Site – Existing Building - Building Plan

Revise: E15.4 to read: Transportation of all waste and materials through Occupied Areas of the building is limited to outside normal operating hours stated in E3.2 along predetermined routes and must be covered or placed within carts. Clean-up waste routes and loading area after each load. Use asbestos abatement precautions if appropriate or requested by the Contract Administrator or representative

DRAWINGS

Add: 1077-2018_Addendum_3-Reference_Drawing_D-6738-R8

Add: 1077-2018_Addendum_3-Reference_Drawing_D-6746-R5

NMS SPECIFICATIONS

Section 28 31 01 Fire Alarm Systems

Add: 1.3.1.10 CAN/ULC-S559-13, Equipment for Fire Signal Receiving Centres and Systems

Add: 1.3.1.11 CAN/ULC-S561-13, Installation and Services for Fire Signal Receiving Centres and Systems

Add: 2.1.11 Cellular Modems: to CAN/ULC-S559-13 and CAN/ULC-S561-13