



1091-2018 ADDENDUM 1

SUPPLY AND DELIVERY OF FIRE HOSES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: November 15, 2018
BY: Colin Carson
TELEPHONE NO. 204 794-4333

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E2.4(g) to read: Couplings for 2 ½ I.D.: heavy duty bronze or light weight aluminum alloy for municipal use. Expansion ring type rated for 200 PSI. Male and female attached hose thread ODM 3.25 IN. 6 TPI. 8.75 IN.