

**PARTIAL MAIN FLOOR PLAN - DEMOLITION**  
REFLECTED CEILING PLAN ALSO SHOWN FOR CLARITY  
SCALE: 1/8" = 1'-0"

**POWER AND SYSTEMS DEMOLITION NOTES:** "X"

ALSO SEE NOTES & SPECIFICATIONS.  
REFER TO APPLICABLE RENOVATION DRAWING FOR RELOCATED COMPONENTS.  
ALL ABANDONED CABLES TO BE REMOVED AS REQUIRED BY LATEST CANADIAN ELECTRICAL CODE.  
DO NOT DISTURB OR DISCONNECT ANY WIRING & CABLING IN AREA OF WORK REQUIRED FOR OTHER AREAS.


1. REMOVE ALL COMPONENTS WITH DESIGNATION "D" BACK TO SOURCE, UNLESS OTHERWISE NOTED.
2. REMOVE & DISCONNECT ALL MECHANICAL EQUIPMENT (CONDUIT, WIRING, SUPPORTS, ELECTRICAL BOXES, STARTER, DISCONNECT, TIMER, RESET) BACK TO SOURCE - INCLUDING INTERLOCKS TO ASSOCIATE EQUIPMENTS.
3. EXISTING CEILING LUMINAIRES TO REMAIN, UNLESS OTHERWISE NOTED.
4. EXISTING LIGHT SWITCHES TO REMAIN, EXCEPT WALL MOUNTED LIGHT SWITCHES DESIGNATED FOR WALL DEMOLITION & BRANCH CIRCUIT CONNECTED TO NON-DEMOLITION AREA - CIRCUITS TO REMAIN & LIGHT SWITCH DEVICE BOX TO BE TEMPORARILY SUPPORTED.
5. REMOVE PAINT BOOTH LUMINAIRES & LIGHT SWITCH BACK TO SOURCE.
6. RELOCATE ELECTRIC HOT WATER HEATER CIRCUIT TO NEW LOCATION, SEE MECHANICAL DRAWING.
7. REMOVE ALL ELECTRICAL SURFACE MOUNTED COMPONENTS ON WALL BACK TO SOURCE IN AREA SHOWN, THERMOSTATS TO BE RELOCATED AS PER MECHANICAL DRAWINGS.
8. ALL FIRE DETECTION/PREVENTION DEVICES TO REMAIN (E.G., CEILING HEAT DETECTORS, SMOKE DETECTORS, FIRE ALARM PULL STATIONS, COMBINATION HORN STROBES, EMERGENCY LIGHTING).

ABBREVIATIONS	
	DESCRIPTION
A	AMPERE, AMPACITY
AC	ABOVE COUNTER
ACT	ACOUSTIC CEILING TILE
AFF	ABOVE FINISH FLOOR
BFC	BELOW FINISH CEILING
CCT	CIRCUIT, CCT: C= PANEL "B"; CT= CIRCUIT "1" (B1)
CLNG	CEILING
D	DEMOLITION, REMOVE BACK TO SOURCE
DED	DEDICATED CIRCUIT
DSW	DISCONNECT SWITCH
DWG	DRAWING
DW	DISHWASHER
E	EXISTING OR "NO DESIGNATION"
GFCI	GROUND FAULT CIRCUIT INTERRUPTER
HTR	HEATER
HVAC	HEATING, VENTILATING AND AIR CONDITIONING
HZ	HERTZ
JB	JUNCTION BOX
M	METER
MD	MOTION DETECTOR
N	NEW
N.I.C.	NOT IN CONTRACT
NTS	NOT TO SCALE
OC	ON COUNTER
OIC	ON CENTER
OS	OCCUPANCY SENSOR
PNL	PANEL
R	RELOCATED LOCATION
RECPT.	RECEPTACLE
SW	SWITCH
TBD	TO BE DETERMINED
TYP.	TYPICAL
V	VOLT
W	WATT

ELECTRICAL LEGEND	
TYPE	DESCRIPTION
⊕	DUPLEX RECEPTACLE
⊕ <sup>XX</sup>	HEIGHT IN INCHES ABOVE FINISH FLOOR TO CENTERLINE OF DEVICE
⊕ <sub>2</sub>	2-GANG DUPLEX RECEPTACLE
⊕ <sub>2A</sub>	DUPLEX RECEPTACLE WITH (2) 2A USB 2.2 & 3.0 CAPABLE
⊕ <sup>GF</sup>	GROUND FAULT CIRCUIT INTERRUPTER DUPLEX RECEPTACLE
⊕	LIGHT SWITCH, SINGLE POLE
⊕ <sup>DSW</sup>	DISCONNECT SWITCH
⊕ <sup>JB</sup>	JUNCTION BOX
⊕ <sup>FAS</sup>	FIRE ALARM MANUAL PULL STATION
⊕ <sup>FAB</sup>	FIRE ALARM BELL
⊕ <sup>FAS</sup>	FIRE ALARM STROBE SIREN
⊕ <sup>HD</sup>	HEAT DETECTOR, CEILING RECESSED
⊕ <sup>HS</sup>	HEAT DETECTOR, CEILING SURFACE MOUNT
⊕ <sup>PAS</sup>	PUBLIC ADDRESS SPEAKER
⊕ <sup>S</sup>	SPEAKER
⊕ <sup>S</sup>	SPEAKER
⊕ <sup>S</sup>	SPEAKER
⊕ <sup>SVC</sup>	SPEAKER VOLUME CONTROLLER
⊕ <sup>DP</sup>	DATA PORT
⊕ <sup>FDP</sup>	FLOOR PEDESTAL DATA PORT
⊕ <sup>V</sup>	VOICE (PHONE) PORT: CENTREX LAND LINE
⊕ <sup>KPD</sup>	KEY PAD/DISPLAY - SECURITY
⊕ <sup>H</sup>	HORN - SECURITY
⊕ <sup>MD</sup>	MOTION DETECTOR- SECURITY
⊕ <sup>PNL</sup>	ELECTRICAL PANEL
⊕ <sup>T</sup>	THERMOSTAT



KEY PLAN  
SCALE: N.T.S.



AREA OF WORK

**NOTES:**

THESE DRAWINGS SHALL NOT BE SCALED. CONSULT WITH CLIENT AND DESIGNER ON ANY CONCERNS.

ALSO REFER TO ELECTRICAL SPECIFICATIONS.

SUBMISSION OF SITE MARK-UPS, AS-BUILTS, OPERATING & MAINTENANCE MANUALS AND OTHER SUPPORTING DOCUMENTS TO CLIENT ARE MANDATORY AT THE COMPLETION OF THIS PROJECT.

THE CONTRACTOR SHALL VISIT THE SITE AND ENSURE ALL DIMENSIONS, DATUM, AND DETAILED INFORMATION SHOWN ARE CORRECT.

THE CONTRACTOR IS TO REVIEW AND COORDINATE ALL ARCHITECTURAL, MECHANICAL AND ELECTRICAL DRAWINGS FOR ADDITIONAL OPENINGS THROUGH FLOORS, WALLS, AND CEILINGS FOR DUCTS, PIPES & ELECTRICAL RISERS AND ALL OPENINGS NOT SHOWN ON DRAWINGS.

ALL OPENINGS THROUGH FIRE ASSEMBLIES INCLUDING FLOORS AND CEILINGS ARE TO BE FIRE STOPPED AND SEALED WITH UL APPROVED FIRE STOPPING TO MAINTAIN THE INTEGRITY OF THE FIRE SEPARATION, AND PROVIDE A SMOKE-TIGHT BARRIER.

ALL PRODUCTS AND MATERIALS TO BE USED AND INSTALLED SHALL CONFORM WITH MANUFACTURER'S SPECIFICATIONS, APPLICABLE CODES AND AUTHORITY HAVING JURISDICTION.

THE CONTRACTOR SHALL BE RESPONSIBLE TO PATCH AND MAKE GOOD ALL EXISTING CONSTRUCTION AFFECTED BY THE REMOVAL OF ALL ITEMS FORMING PART OF THE RENOVATION WORK.

ALL ABANDONED (KNOWN & UNKNOWN) ELECTRICAL FIXTURES, COMPONENTS, RECEPTACLES & DATA CABLING SHALL BE REMOVED BACK TO SOURCE & TERMINATED AS PER APPLICABLE CODES.

RECONNECT & TEST ALL FIRE PREVENTION EQUIPMENT.

**WARNING:**  
ASBESTOS MAYBE PRESENT BEHIND WALLS, CEILING SPACE & FLOORS.  
IF ASBESTOS & ANY HAZARDOUS MATERIAL IS FOUND, STOP WORK IMMEDIATELY & CONTACT CITY OF WINNIPEG, CENTRAL CONTROLS, PH: 204-986-2351.

No.	REVISION/DESCRIPTION	BY	DATE
0	ISSUED FOR CONSTRUCTION	DTA	2018.12.06

DRAWN	CHECKED	DESIGNED	APPROVED
DTA	DTA	DTA	DTA
DATE: 2018.12.06	USER APPROVAL		

**THE CITY OF WINNIPEG**  
PLANNING, PROPERTY AND  
DEVELOPMENT DEPARTMENT  
MUNICIPAL ACCOMMODATIONS DIVISION  
3-65 GARRY STREET, R3C 4K4

**PROJECT**  
PUBLIC WORKS SOUTH YARD  
RENOVATIONS TO ENLARGE PARKS VEHICLE  
STORAGE GARAGE  
1539 WAVERLEY STREET

**SHEET TITLE**  
PARTIAL MAIN FLOOR PLAN  
ELECTRICAL DEMOLITION AND RENOVATION

SCALE: AS SHOWN PROJECT No: 2018-018 SHEET No: **E1**