



SYMBOL LEGEND	
(T)	THERMOSTAT
⊕	DUPLEX RECEPTACLE
⊕ <sub>GFI</sub>	GFI DUPLEX RECEPTACLE
▬ <sub>BBH</sub>	BASEBOARD HEATER
(FE)	FIRE EXTINGUISHER
➔	DATA JACK

**GENERAL NOTES:**

1. ALL OUTLETS INSIDE UNHEATED STORAGE SHED TO BE INSTALLED AT 1067mm A.F.F. UNLESS OTHERWISE NOTED
2. CONTRACTOR TO COORDINATE INSTALLATION OF ONE PHONE LINE INTO THE BUILDING – INCLUDING CONNECTION TO SERVICE PROVIDER NETWORK. LOCATE ONE (1) VOICE – DATA JACK IN ELECTRICAL ROOM. LOCATION TO DETERMINED BY CONTRACT ADMINISTRATOR.

ELECTRICAL FIXTURE SCHEDULE		
LABEL	FIXTURE	SPECIFICATION
BBH	BASEBOARD HEATER	DIMPLEX LINEAR CONVECTOR 2500W, 240V - SINGLE PHASE #LC6025W31 (1500mm LONG) OR APPROVED EQUAL IN ACCORDANCE WITH B7.
T	THERMOSTAT	DIMPLEX LINE VOLTAGE THERMOSTAT 240V, 7-DAY PROGRAMMABLE. OR APPROVED EQUAL IN ACCORDANCE WITH B7.

**GENERAL NOTES:**

1. ALL THERMOSTATS TO BE GANGED TO ONE THERMOSTAT LOCATED IN WATER ROOM.

ALL EXTERIOR RECEPTACLES TO BE WEATHER-PROOF; TYP

1 ELECTRICAL POWER PLAN  
1 : 50

