



296-2018 ADDENDUM 1

2018 WATERMAIN RENEWALS – CONTRACT NO. 7

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: April, 18, 2018
BY: Rob Sherlock
TELEPHONE NO. 204 478-8993

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART A – BID SUBMISSION

Replace: 296-2018 Bid Submission with 296-2018 Addendum 1 - Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

Form B(R1): Various quantity changes and item additions.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D18.1(a) to read: Tache Avenue watermain renewal – two-thousand dollars (\$2,000);

Revise: D18.1(b) to read: Beresford Avenue watermain renewal (Daly Street to Nassau Street) – two-thousand dollars (\$2,000);

Revise: D18.1(c) to read: Beresford Avenue watermain renewal (Nassau Street to Osborne Street) – two-thousand dollars (\$2,000);

PART E – SPECIFICATIONS

Add: E5.11 Contaminated soil with high concentrations of extractable petroleum hydrocarbon may be encountered during excavation on Beresford Avenue between the Public Lane approximately 35 metres west of Osborne Street and Osborne Street. Therefore oil and gas resistant gaskets are to be used between the Public Lane and Osborne Street.

Add: E5.12 Gaskets shall be oil and gas resistant Nitrile conforming to ASTM F477 and shall be supplied by the pipe manufacturer.

Add: E5.13 Water mains installed with oil and gas resistant gaskets will be measured on a linear metre basis, and paid for under the unit price for "Watermain Renewal – 150mm c/w Nitrile Gaskets". The bid price will be cull compensation for all gaskets required for pipe, fittings, valves, hydrant assemblies, couplings and appurtenances. No additional payment will be made for disposal of contaminated soil.