



GENERAL NOTES

1. ALL LADDER RUNGS AND RAILS SHALL BE 1-1/4" [32mm] SCHEDULE 40 PIPE.
2. THE TOP OF THE LADDER MUST BE FLARED AS INDICATED ON THE DRAWING.
3. THE TOP OF THE LADDER RAILS MUST BE CAPPED.
4. THE BOTTOM OF THE LADDER RAILS MUST REMAIN OPEN.
5. THE BOTTOM RUNGS MUST NOT BE GREATER THAN 12" [305mm] FROM THE LOWER ROOF LEVEL, LANDING OR GRADE.
6. LADDER MOUNTING BRACKETS MUST BE SPACED NOT GREATER THAN 10 FT [3m].
7. THE LOWER MOUNTING BRACKET MUST BE LONGER THAN THE UPPER BRACKET TO ACHIEVE A 2% INCLINE PLANE.
8. THE TOP OF THE LADDER MUST BE A MINIMUM OF 6" [152mm] FROM THE WALL.
9. ALL LADDER RUNGS MUST BE FITTED WITH 14" [356mm] "SAFETY TREAD" PART NO. LR6253B. THIS TREAD MUST BE STITCH WELDED WITH 1" [25mm] LONG WELDS AT EACH END AND ON IN THE CENTER. THIS IS TO BE DONE ON BOTH SIDES OF THE RUNG.

RMIS ENGINEERING



389 MAXWELL CRESCENT
Regina, SK S4N 5X9
www.rmiseng.ca
Phone 306.352.4606
Fax 306.352.4607



WESTRIDGE
COMMUNITY CENTRE
C.13.MB.35-18.04.03

3 MARSHALL CRESCENT
WINNIPEG, MB R3T 4C3

CITY OF WINNIPEG

4TH FLOOR - 185 KING STREET
WINNIPEG, MB R3B 1J1

No.	DATE	DESCRIPTION

DESIGNED BY SMC 04/17/2018
DRAWN BY SED 04/17/2018
REVIEWED BY SMC 04/17/2018

LADDER
DETAILS

S 4.01