




26 June 2018

186936-02-PLAN-CON-C1.dwg



1 BY-PASS CHAMBER SECTION
C-1

- CONSTRUCTION NOTES:
- ELEVATIONS SHOWN ARE APPROXIMATE GEODETIC AND CONTRACTOR TO CONFIRM.
 - CONTRACTOR TO LOCATE EXISTING FORCEMAIN ON BY-PASS CONNECTION INSTALLATION.
 - IF MANHOLE IS LOCATED IN ROAD, RIM ELEVATION SHOULD BE FLUSH WITH ROAD.
 - IF MANHOLE IS LOCATED IN GRASS, RIM ELEVATION SHOULD BE 200mm ABOVE GROUND.
 - VALVES WILL BE SUPPLIED BY THE CITY.

NOT FOR CONSTRUCTION

APEGM
Certificate of Authorization
Dillon Consulting Limited (MB)
No. 1789 Date: _____

NO.	REVISIONS	DATE	BY
0	ISSUED FOR TENDER	06/29/18	CP

DESIGNED BY	CP	CHECKED BY	MH
DRAWN BY	GLG	APPROVED BY	MH
HOR. SCALE	1:100	RELEASED FOR CONSTRUCTION	
VERTICAL			
DATE	June 2018	DATE	

ENGINEER'S SEAL

CONSULTANT PROJECT NUMBER
18-6936

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT

HAWTHORNE WASTEWATER PUMPING STATION UPGRADES

CIVIL - SITE PLAN, BY-PASS CONNECTION DETAIL

CITY DRAWING NUMBER
1-0145L-C0001-001

SHEET 02 OF 21

CONSULTANT DRAWING NUMBER
C-01