



773-2018 ADDENDUM 1

SUPPLY, DELIVERY AND INSTALLATION OF BREATHING AIR COMPRESSORS

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: October 15, 2018
BY: Ron Martin
TELEPHONE NO. 204 986-6864

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART A – BID SUBMISSION

Replace: 773-2018 Bid Submission with 773-2018 Addendum 1 - Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

Form B(R1): **Added Item No. 2 – Installation Charge.**

Page numbering on some forms may be changed as a result.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D9.1 to read: Goods shall be delivered and installed within **ninety (90)** Calendar Day(s) of the award of Contract, f.o.b. destination, freight prepaid to:

Winnipeg Transit Stores
421 Osborne Street
Winnipeg, MB
R3L 2A2

PART E – SPECIFICATIONS

Revise: E2.4 to read: **Installation information:**

Add: E2.4 (a) Compressors must be able to attach to the existing condensate separator, air intake ducting, water supply and electrical lines.

Add: E2.4 (b) Air compressors will be located inside the maintenance facility. They will be exposed to the elements (dust, fumes) and do not have their own room.

Add: E2.4 (c) Total area for the air compressors measures one hundred eighty- three (183) inches long x sixty-one (61) inches wide. The compressors have thirty (30) inches of clearance in front and fifty-one (51) inches of clearance between each other.

Add: E2.4 (d) The compressors are freestanding.

- Add: E2.4 (e) The air intake supply is eight (8) inches at the supply manifold located directly above the compressors. The manifold steps down six (6) inches above each compressor where it further reduces and connects via a four (4) inch PVC pipe.
- Add: E2.4 (f) Supply power to each of the compressors is through a Tech cable rated at sixty (60) Amps, six hundred (600) Volts, three (3) phase from an eight (8) Amp breaker to a transformer box that steps the voltage down to four hundred sixty (460) volts.
- Add: E2.4 (g) There is one water supply connection at each compressor which is ½" copper pipe. There are four (4) condensate drains at each compressor that are also ½ inch copper pipe.
- Add: E2.4 (h) Any modifications required to install the new compressors will be required to meet all local regulations, standards, and/or guidelines.
- Add: E2.4 (i) Site viewing may be arranged through the Contract Administrator identified in D3.1.
- Add: **E3** **APPROVED PRODUCTS**
- Add: E3.1 The following products are approved;
- Add: E3.1 (a) Atlas Copco model #: AQ22VSD Compressor.
- Add: E3.1 (b) Wise Air model# WIS 30 IVR Compressor.