

805-2018 ADDENDUM No. 2

BOILER ROOM COMBUSTION AIR UPGRADE AT PAN AM POOL – 25 POSEIDON BAY

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: September 10, 2018
BY: P. Silva, P.Eng.
TELEPHONE NO. 204 896-1209

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

DIVISION 23:

Section 23 31 13.02 - METAL DUCTS - HIGH PRESSURE TO 2500 PA

Add: 2.6 Intake Hood

700mm x 700mm (28" x 28") throat, 1244mm x 1219mm x 482mm (49" w x 48" l x 19" h) hood, 863mm x 863mm (34" x 34") curb cap, precision formed locked rib construction, galvanized steel construction, 0.5 in. galvanized steel mesh birdscreens, heavy gauge galvanized steel support members, hood can be removed completely from the base or hinged open, ducted installation, recommended roof opening dimension is at least 2.5 in. larger than the damper size. Coating: Permator Concrete Gray-RAL 7023 entire unit c/w (20" x 34" x 34") galvanized insulated curb.

Acceptable Product: "Greenheck" FGI-28x28 c/w Model GPI curb, Loren Cook or approved equivalent in accordance with B7.

Add: 2.7 Exhaust Hood

700mm x 700mm (28" x 28") throat, 1244mm x 1219mm x 482mm (49" w x 48" l x 19" h) hood, 863mm x 863mm (34" x 34") curb cap, precision formed locked rib construction, galvanized steel construction, 0.5 in. galvanized steel mesh birdscreens, heavy gauge galvanized steel support members, hood can be removed completely from the base or hinged open, ducted installation, recommended roof opening dimension is at least 2.5 in. larger than the damper size. Coating: Permator Concrete Gray-RAL 7023 entire unit c/w (20" x 34" x 34") galvanized insulated curb.

Acceptable Product: "Greenheck" FGR-28x28 c/w Model GPI curb, Loren Cook or approved equivalent in accordance with B7.