CONTROL ELECTRICAL ROOM ROOM EXISTING 1600A SWITCHGEAR + -NEW BREAKERS -EXISTING CORRIDOR PUMPHOUSE 🚙 4x3c, 2AWG, TECK90 1000V IN 2x4" CONDUITS AND 2x4" CONDUITS SPARE. TRENCH DETAIL REFER TO DRAWING E002 -GATEHOUSE TRANSFER SWITCH PENETRATE THROUGH SIDE WALL OF SKYLIGHT AND DROP DOWN TO LCP-PG971 SIDE FACE OF BEAM ABOVE CRANE - FIRE PUMP ≈ P−G971 DROP DOWN FACE OF COLUMN EMT CONDUITS TRANSFER SWITCH LCP-PG972 P-G972 PUMPHOUSE & GATEHOUSE - PLAN

GENERAL NOTES

- 1. ALL UTILITIES IN AREA OF EXCAVATION TO BE LOCATED; SOFT DIG TO CONFIRM UTILITIES.
- 2. NOTIFY THE CONTRACT ADMINISTRATOR OF EXISTING SERVICES, UTILITIES, STRUCTURES OR OBSTRUCTIONS THAT ARE NOT SHOWN ON THE DRAWINGS OR ARE IN DIFFERENT LOCATIONS THAN SHOWN ON THE DRAWINGS AND ARE IN CONFLICT WITH THE WORK.
- 3. THE CONTRACT ADMINISTRATOR WILL DETERMINE IF THE ALIGNMENT OR GRADE OF THE WORK CAN BE ALTERED OR IF THE EXISTING SERVICE, UTILITY, STRUCTURE OR OBSTRUCTION HAS TO BE RELOCATED OR REMOVED AND REPLACED. THE CITY WILL PAY COSTS FOR AUTHORIZED CHANGES IN WORK IN ACCORDANCE WITH CLAUSE GC:7 OF THE GENERAL CONDITIONS.
- 4. REMOVE ABANDONED SERVICES THAT OCCUR IN EXCAVATIONS FOR AND ADJACENT TO THE WORK.
- 5. EARTHWORK AND GRADING TO BE DONE TO CITY OF WINNIPEG CONSTRUCTION STANDARD AS APPLICABLE: CW3170 AND CW3110 SUB-GRADE, SUB-BASE AND BASE COURSE CONSTRUCTION.
- 6. SITE RESTORATION TO BE DONE TO CITY OF WINNIPEG STANDARD AS APPLICABLE: CS3150, CW3520, CW3530 AND CW3540 (SOD, SEED, ETC.)
- 7. CONTRACTOR TO ADVISE CONTRACT ADMINISTRATOR IF UNSUITABLE SUBGRADE IS ENCOUNTERED.

DRAWING NOTES:

- 1. PROVIDE SEALS AT ALL EXTERIOR PENETRATIONS.
- 2. SCAN THE SLAB AND LOCATE THE CONDUIT PENETRATION IN ORDER TO CUT MAXIMUM ONE OUTER BAR IN EACH DIRECTION.


BID OPPORTUNITY NO. 502-2017

REFERENCE DRAWINGS

DRAWING NUMBER

Certificate of Authorization AECOM Canada Ltd. No. 4671 Date: 18/05/09







E0007

## THE CITY OF WINNIPEG **WATER AND WASTE DEPARTMENT**

SHOAL LAKE **AQUEDUCT INTAKE FACILITY** FIRE PUMP UPGRADES

**ELECTRICAL** 

PUMPHOUSE PLAN

CITY DRAWING NUMBER

1-0600A-E0007-001 0