



- NOTES:**
1. CONFIGURE FLOW METER, FIT-008 FOR 4-20mA PASSIVE OUTPUT.

File Name: c:\project\working directory\active\40\call\0713845175009-13-chevrier-loops.dwg

								THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION		DESIGNED BY B.L.M.	CHECKED BY B.L.M.	2019 REHABILITATION OF PUBLIC WATER SERVICE OUTLET PAVEMENT WORKS, BUILDING REPAIRS, AND ELECTRICAL UPGRADES CHEVRIER BOULEVARD 0801-FIT-008 LOOP DIAGRAM		SHEET 19 OF 20	
								THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION		DRAWN BY S.C.K.	APPROVED BY			CITY DRAWING NUMBER D-14928	
1	ISSUED FOR BIP OP 103-2019	04/15/19	B.L.M.	DATE: 17/07/06 PROJECT No. 175009											
0	ISSUED FOR 90% REVIEW	03/07/19	C.A.L.												
NO.	REVISION	DATE	BY												