



Control #1
 46.6 - L.W.L.
 48.6 Start #1
 49.1 Start #2
 Control #2
 48.5 L.W.L.
 50.1 Start #3
 51.1 Start #4
 52.5 H.W. Alarm

Control #7
 46.5 L.W.L.
 51.5 - Start engine } approximate calculation
 52.0 - Start pumps }

| NO. | DESCRIPTION | DATE | OWN. | CKD. |
|-----------|-------------|------|------|------|
| REVISIONS | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |



APPROVED BY _____ DATE _____

MUNICIPALITY OF ASSINIBOIA
 WESTWOOD DR. SEWAGE PUMPING STATION
 MECHANICAL SECTIONS & DETAILS

UNDERWOOD McLELLAN & ASSOCIATES
 LIMITED
 CONSULTING PROFESSIONAL ENGINEERS
 MANITOBA SASKATCHEWAN ALBERTA BRITISH COLUMBIA

| | |
|---------------------------|-------------------------|
| DRAWN BY E.B. | DESIGNED BY <i>Am S</i> |
| CHECKED BY | CHECKED BY <i>Am S</i> |
| DATE DRAWN NOV. 25, 1988. | SCALE 3/8" = 1" |
| JOB NO. 41-02-063-98-01 | DRAWING NO. |
| SHEET 3 OF 6 | |

M-3

file # SP10288