SITE

9111	_
MMDDYYYY HH: MM: SS	7
YES	1
CENTRAL	1
PTH 1 EASTBOUND	1
67.28	1
000000A	1
CROSSING	1
DDMMYYYY	1
CELSIUS	1
1	1
60	1
2 620 100 100 99.01	1
COLLECTOR	1
7 620 00 0000	1
1	1
GEN/ATCS	1
DISABLED	1
DIRECT (RS232)]
AUX	1
NONE]
57600]
8]
NONE	1
1]
NONE]
9600	
8]
NONE]
1]
NONE	
9600]
8]
NONE]
1	
NONE	
	YES CENTRAL PTH 1 EASTBOUND 67.28 000000A CROSSING DDMMYYYYY CELSIUS 1 60 2 620 100 100 99.01 COLLECTOR 7 620 00 0000 1 GEN/ATCS DISABLED DIRECT (RS232) AUX NONE 57600 8 NONE 1 NONE 1 NONE 9600 8 NONE 1 NONE

	SET UP		
1	RESET NAMES MODULES	YES OR NO	YES
1	AC OFF ALARM TIME	(1-180) MINUTES	60 MINUTES
1	MINIMUM WARNING TIME	(20-90 DEF: 20)SECONDS	35 SECONDS
1	DESIRED WARNING TIME	(20-99 DEF: 25)SECONDS	35 SECONDS
	IGNORE WARNING TIME BELOW	(0-10 DEF: 3)SECONDS	3 SECONDS
1	XR IS UP WHEN INPUT IS	NOT ENERGIZED—ENERGIZED—UNUSED	NOT ENERGIZED
1	HOW MANY GATES ?	(0-4)	0
1	GATE 1 DOWN	NOT ENERGIZED—ENERGIZED	N/A
1	GATE 2 DOWN	NOT ENERGIZED—ENERGIZED	N/A
	GATE 3 DOWN	NOT ENERGIZED—ENERGIZED	N/A
	GATE 4 DOWN	NOT ENERGIZED-ENERGIZED	N/A
	HOW MANY TRACK ?	(1 – 2)	1
	IF TRACKS = 1	ISAND ONLY OPPERATION	NO
	IF TRACKS = 2	ISAND ONLY OPPERATION	N/A
	HOW MANY ILODS ?	(0 - 2)	2
	IF 1 OR 2 IS SELECTED	MINIMUM FL. RATE (35-55)	55
	GATE NOT DOWN ALARM TIME	(8 - 30 DEF:15)	N/A
	CROSSING ACTIVE ALARM AFTER	(20 - 60 DEF:20)	20 MINUTES
	Flashing trouble light output ?	YES OR NO	YES
	DEGITAL INPUTS NAMES		USER DEFINED
	XB12 LOW VOLTAGE ALARM	(90 – 150) IN TENTHS	136
	B12 LOW VOLTAGE ALARM	(90 – 150) IN TENTHS	107
	B14 LOW VOLTAGE ALARM	(90 - 150) IN TENTHS	107

EDIT DIGITAL INPUTS	YES OR NO	YES	
INPUT 1 ALGRTHN	DISCRETE - MTSS - GFT	DISCRETE	ж
INPUT 2 ALGRTHN	DISCRETE - MTSS - GFT	DISCRETE	DEFAULT
INPUT 3 ALGRTHN	DISCRETE - MTSS - GFT	DISCRETE	DEFAULT
INPUT 4 ALGRTHN	DISCRETE - MTSS - GFT	DISCRETE	DEFAULT
INPUT 5 ALGRTHN	DISCRETE - MTSS - GFT	DISCRETE	DEFAULT
INPUT 6 ALGRTHN	DISCRETE - MTSS - GFT	DISCRETE	DEFAULT
INPUT 7 ALGRTHN	DISCRETE - MTSS - GFT	DISCRETE	W-BELLK
INPUT 8 ALGRTHN	DISCRETE - MTSS - GFT	DISCRETE	WT
INPUT 9 ALGRTHN	DISCRETE - MTSS - GFT	DISCRETE	ISL
INPUT 10 ALGRTHN	DISCRETE - MTSS - GFT	DISCRETE	ET
INPUT 11 ALGRTHN	DISCRETE - MTSS - GFT	DISCRETE	DEFAULT
INPUT 12 ALGRTHN	DISCRETE - MTSS - GFT	DISCRETE	DEFAULT
INPUT 13 ALGRTHN	DISCRETE - MTSS - GFT	DISCRETE	DEFAULT
INPUT 14 ALGRTHN	DISCRETE - MTSS - GFT	DISCRETE	DEFAULT
INPUT 15 ALGRTHN	DISCRETE - MTSS - GFT	DISCRETE	DEFAULT
INPUT 16 ALGRTHN	DISCRETE - MTSS - GFT	DISCRETE	DEFAULT
INPUT 17 ALGRTHN	DISCRETE - MTSS - GFT	DISCRETE	DEFAULT
INPUT 18 ALGRTHN	DISCRETE - MTSS - GFT	DISCRETE	TESTSW
EDIT BATTERY	YES OR NO	YES	· ·

XB12 - B12 - B14 - AC/POR XB12 XB12 - B12 - B14 - AC/POR B12

NO

NO

LED	LABEL	OFF=	ON=	LED	LABEL	OFF=	ON=
01	CROSSING ACTIVE	XR / NXT / SXT ALL UP OR 1BELLK DOWN	XR / NXT / SXT DOWN OR 1BELLK UP	09	ET 1 OCCUPIED	EAST TRACK 1 NOT OCCUPIED	EAST TRACK 1 OCCUPIED
02	GATE OFF	GODK ON	GODK OFF	10	WT 1 OCCUPIED	WEST TRACK 1 NOT OCCUPIED	WEST TRACK 1 OCCUPIED
03	GATE CONTROL 1	1GCK ON	1GCK OFF	11	ISL 2 OCCUPIED	ISLAND 2 NOT OCCUPIED	ISLAND 2 OCCUPIED
04	GATE UP	GPK ON (GATE UP)	GPK OFF	12	ET 2 OCCUPIED	EAST TRACK 2 NOT OCCUPIED	EAST TRACK 2 OCCUPIED
05**	GATE DOWN 1	1GDK OFF (GATE 1 NOT DOWN)	1GDK ON (GATE 1 DOWN)	13	WT 2 OCCUPIED	WEST TRACK 2 NOT OCCUPIED	WEST TRACK 2 OCCUPIED
06**	GATE DOWN 2	2GDK OFF (GATE 2 NOT DOWN)	2GDK ON (GATE 2 DOWN)	14	GATE CONTROL 2	2GCK ON	2GCK OFF
07	BELL CONTROL 1	1BELLK DOWN	1BELLK UP	15	BELL CONTROL 2	2BELLK DOWN	2BELLK UP
08	ISL 1 OCCUPIED	ISLAND 1 NOT OCCUPIED	ISLAND 1 OCCUPIED	16	AC POWER	POR ON	POR OFF

YES OR NO

YES OR NO

YES OR NO

YES OR NO

BATT 1

EDIT RELAY

EDIT INDICATOR LEADS

EDIT TEST LEADS

EDIT ISLOD SENSORS

(FOR ADDING SSCC IN SEAR) MENU SELECTIONS CONFIGURATION / MODULES /

ADD MODULES / SSCC / SSCC1 / ATCS ADDRS / ADDRS (NOTE 1)

COMPILE

EXIT TO MENU BACK TO CONFIGURATION SAVES CHANGES

CURRENT SOFTWARE REVISION: EXECUTIVE: 9v645a01.w ALARM CONDITIONS

GREEN UPON START OF THE APPLICATION PROGRAM.
YELLOW FLASHING IF AC POWER IS LOST FOR LESS THAN 180 MINUTES.
YELLOW STEADY IF AC POWER LOST FOR LESS THAN 180 MINUTES AND THEN RESTORED.
RED FLASHING IF AC POWER IS LOST FOR 180 MINUTES OR MORE.
RED STEADY IF AC POWER LOST FOR 180 MINUTES OR MORE AND THEN RESTORED FOR A MINIMUM OF 5 MINUTES.

BATTERY ALARM (T2)

AC POWER ALARM (T1)

GREEN UPON START OF THE APPLICATION PROGRAM.
YELLOW FLASHING IF BATT. POWER MOVES OUT OF RANGE, BUT NOT LONG ENOUGH FOR ALARM.
YELLOW STEADY IF BATT. POWER MOVED OUT OF RANGE, NO ALARM GENERATED AND IS NOW BACK IN RANGE.
RED FLASHING IF BATTERY HAS BEEN OUT OF RANGE FOR OVER 5 SECONDS.
RED STEADY IF POWER MOVED OUT OF RANGE, GENERATED ALARM AND IS NOW BACK IN RANGE FOR 10 SEC.

LIGHT OUT DETECTED (T3)

GREEN UPON START OF THE APPLICATION PROGRAM.
FLASHER FAILURE:
YELLOW FLASHING IF THE FLASH RATE OF ANY LAMP DURING THE LAST ACTIVATION IS ABOVE 65 FPM
OR BELOW THE MENU SETTING OF 35 OR 55 FPM.
YELLOW STEADY IF THE FLASH RATE HAS RETURNED TO NORMAL SINCE THE FLASH RATE WAS LAST IN ERROR

RED FLASHING IF ANY NUMBER OF BURNT BULB IS DETECTED.

WARNING TIME TRACK 1 OR TRACK 2 ALARM (T4)

GREEN UPON START OF THE APPLICATION PROGRAM.
YELLOW FLASHING IF LAST TRAIN BY CROSSING HAD A WARNING TIME LESS THAN DW BUT GREATER THAN MW.
YELLOW STEADY IF PRIOR TRAIN HAD A WARNING TIME LESS THAN DW AND LAST TRAIN HAD NORMAL WARNING TIME.
RED FLASHING IF LAST TRAIN BY CROSSING HAD A WARNING TIME ALARM (LESS THAN MW)
RED STEADY IF PRIOR TRAIN HAD ALARM AND LAST TRAIN HAD NO ALARM.

CROSSING ACTIVE TOO LONG (T5)

GREEN UPON START OF THE APPLICATION PROGRAM.
RED FLASHING IT CROSSING ACTIVE IS THE FOR USER SPECIFIED NUMBER OF MINUTES.
RED STEADY IF ALARM CONDITION OCCURRED AND IS CURRENTLY NOT IN ALARM.

GREEN UPON START OF THE APPLICATION PROGRAM.
RED FLASHING IF CURRENTLY IN ALARM.
RED STEADY IF ALARM OCCURRED AND IS PRESENTLY CLEARED.

GREEN UPON START OF THE APPLICATION PROGRAM.
RED FLASHING IF CURRENTLY IN ALARM.
RED STEADY IF ALARM OCCURRED AND IS PRESENTLY CLEARED AFTER PROPER GATE OPERATION.

GREEN UPON START OF THE APPLICATION PROGRAM.
RED FLASHING IF GATE OFF IS DETECTED.
YELLOW FLASHING IF CURRENTLY IN ALLARM FOR GATE UP INPUT REMAINS
LOW FOR 20 SEC. AFTER GATE CONTROL HAS ENERGIZED OR IF GATE UP INPUT REMAINS LOW FOR 30 MINUTES
WITH ALL CCK'S UP.

YELLOW STEADY IF THE YELLOW FLASHING ALARM OCCURRED AND IS PRESENTLY CLEARED.

TROUBLE INDICATION (RELAY OUTPUT 2 USED TO POWER TRBR RELAY) TROUBLE RELAY DE-ENERGIZED :

TROUBLE RELAY ENERGIZED:

- AC POWER OK - AC POWER OFF FOR OVER AC OFF ALARM TIME

- BATTERIES OK - ONE OR MORE OF BATTERY BANKS IS OUT OF RANGE FOR OVER 5 SECONDS

NOTES:

1- USED SAME ATCS ADDRS ON SSCCIV

** THE GATE DOWN LEDS WILL ALWAYS BE ON WHEN GATE IS DOWN. THE LOGIC TAKES CARE OF MAPPING NORMALLY-OPEN OR NORMALLY-CLOSED INPUTS TO TRUE AND FALSE CONDITIONS. LEDS 01-16 ALL OFF IN NORMAL LOGIC STATE (NO TRAIN)

BATTERY INPUT CONFIGURATION

INPUT	USAGE	LABEL	NORMAL RANGE
1	LIGHT BATTERY	XB12/XN12	MINIMUM LEVEL - 18 VDC
2	STANDBY BATTERY	B12/N12	MINIMUM LEVEL - 18 VDC
3	POR	POR	POWER ON > 0.5 VDC

(WHEN REQUIRED)

APPLICATION: CNDC005.cdl

ENGINEER'S SEAL FLEV CONSTRUCTION COMPLETION DATE: YYYY MM DD DESIGNED BY CHECKED JAB(WSP) HH(WSP) DRAWN APPROVED JAB(WSP) RY(WSP) RELEASED FOR CONSTRUCTION HORIZONTAL CONSULTANT DRAWING NUMBER NTS 2020-01-31 WSP VERTICAL 0 ISSUED FOR TENDER GWWD067.23PA014_SW NO. REVISIONS DATE BY DATE 2020 01 31 DATE YYYY-MM-DD PLOT DATE: 2020 01 31

Winnipeg

THE CITY OF WINNIPEG

WATER AND WASTE DEPARTMENT ENGINEERING DIVISION

THE GREATER WINNIPEG WATER DISTRICT RAILWAY PTH 1 HIGHWAY CROSSING WARNING SYSTEMS Mi.67.18 & Mi.67.28 CITY DRAWING NUMBER

Mi.67.28 EASTBOUND SEARII PROGRAM DATA|1-0754R-E0014-001

SHEET 14 OF 20

BID OPPORTUNITY: XXX-20XX CONTRACT NUMBER: X

FILE PATH: C: \Users\cab069559\OneDrive - WSP 0365\My Documents\5 - Winnipeg Crossings\Design\CAD\FILE NAME: GWWD067.23PA014_SW.dwg