

GENERAL NOTES

- A. ALL ABANDONED EQUIPMENT AND SERVICES WITHIN AREA OF WORK SHALL BE REMOVED.
- B. THIS BUILDING MAY CONTAIN ASBESTOS. REFER TO FRONT END SPECIFICATIONS FOR FURTHER INFORMATION.
- C. REFER TO ROOF DETAILS FOR ALL NEW AND CAPPED OPENINGS.

DEMOLITION KEY NOTES

- REMOVE EXISTING INFRARED HEATER AND ASSOCIATED CONTROLLER AND THERMOSTAT.
- 2. EXISTING ROOF DRAINS TO REMAIN.
- 3. REMOVE EXISTING THERMOSTAT AND SWITCH SERVING INFRARED HEATERS.
- 4. EXISTING MAKE-UP AIR UNIT TO REMAIN.
- AT INTERIOR OF WALL.

5. DEMOLISH AND REMOVE VENT UP TO EXTERIOR WALL. CAP VENT


- DEMOLISH AND REMOVE NATURAL GAS PIPING AND VENT. REPAIR AND SEAL PRV VENT ROOF OPENING TO MATCH ADJACENT CONSTRUCTION AND FINISH.
- 7. DEMOLISH AND REMOVE EXISTING SIDEWALL SPRINKLER HEAD PROVIDING COVERAGE BELOW OVERHEAD DOOR.
- 8. DEMOLISH AND REMOVE VENT THROUGH ROOF. REPAIR AND SEAL ROOF OPENING TO MATCH ADJACENT CONSTRUCTION AND
- 9. EXISTING UPRIGHT SPRINKLER AT HIGH LEVEL NOT SHOWN TO
- WANDS, TRAFFIC LIGHTS AND CONTROLLERS. RETAIN EXISTING FRAME AND MAKE SUITABLE FOR INSTALLATION OF NEW DOOR. REQUEST REVIEW BY THE CONTRACT ADMINISTRATOR.
- 13. DEMOLISH AND REMOVE EXISTING TRAFFIC LIGHTS AND PATCH


OPENING.

- 10. REMOVE EXISTING OVERHEAD DOOR AND ALL ASSOCIATED HARDWARE, COUNTER BALANCE, DOOR TRACK, OPEN AND CLOSE
- 12. DEMOLISH AND REMOVE EXISTING DOOR OPEN AND CLOSE

11. DEMOLISH AND REMOVE EXISTING DOOR CONTROLLER.

- 14. EXISTING TIMING WAND AND ASSOCIATED CONTROLLER AND TIMING LIGHTS TO REMAIN.
- 15. EXISTING EXTERIOR ELECTRIC SNOW MELT RADIANT FLOOR LOOP AND ASSOCIATED CONTROLLER TO REMAIN.











CITY OF WINNIPEG FORT ROUGE TRANSIT BASE - RAPID ROLL DOORS AND RADIANT HEATERS REPLACEMENT

WINNIPEG

MANITOBA

J. T. HORROCKS Member 24767

MAIN FLOOR AND ROOF PLAN -SERVICE BAY - DEMOLITION -MECHANICAL

APRIL 2019	
	19-028-01
Drawing Number	Sheet Order
 	1 OF 4
-	Drawing Number