DETERMINE LOCATION OF UNDERGROUND UTILITIES BEFORE PROCEEDING WITH CONSTRUCTION. LOCATION OF UNDERGROUND STRUCTURES AS SHOWN ARE BASED ON BEST INFORMATION AVAILABLE, BUT NO GUARANTEE IS GIVEN THAT ALL EXISTING UTILITIES ARE SHOWN AND EXACT LOCATIONS OF ALL UNDERGROUND INCLUDING CONNECTIONS MUST BE CHECKED WITH THE UTILITY CONCERNED BEFORE PROCEEDING WITH CONSTRUCTION.

GENERAL

-DRAWING SHOULD BE USED AS A GENERAL GUIDE. EXACT SIZE, ALONG WITH STYLE AND LOCATION OF VEHICLE GATES, ACCESS, PLAYER'S GATES & PLAYER'S BOXES LOCATION, GRADING AND LIGHTING REQUIREMENTS TO BE SHOWN ON PROJECT SITE PLAN.

APPLICABLE CITY OF WINNIPEG STANDARD SPECIFICATIONS

-CW 3110-R5 -SUB-GRADE, SUB-BASE & BASE COURSE CONSTRUCTION CW 3410-R5 -ASPHALT CONCRETE PAVEMENT WORK CW 3170-R5-EARTHWORK &

HOCKEY RINK AND PLAYER'S BOXES

- -ALL POST UPRIGHTS TO BE MINIMUM 3 1/2" Ø SCHEDULE 40 STEEL PIPES.
- -UPRIGHT POSTS TO BE LOCATED AS SHOWN ON THE DRAWINGS. POSTS TO BE PUSHED INTO GROUND & SHALL BE PLUMB IN ALL DIRECTIONS.
- -VEHICLE GATES (OPTION 'B') REQUIRES POST UPRIGHTS ENCASED IN CONCRETE (GATE ONLY).
- -ALL LUMBER & PLYWOOD TO BE PRESSURE TREATED (P.T.). -LUMBER WITH LOOSE KNOTS, SURFACE IMPERFECTIONS OR SPLITS WILL NOT BE ACCEPTED.
- -ALL FASTENERS TO BE GALVANIZED. NAILS TO BE 3 1/2" ARDOX & CLINCHED. FASTEN ARDOX NAILS WITH THE GRAIN.
- -ALL CARRIAGE BOLTS, BARREL BOLTS, NUTS & WASHERS TO BE CADMIUM PLATED.
- -CARRIAGE BOLTS TO BE USED TO FASTEN WOOD FRAMING TO SLEEVES & GATE HARDWARE.
- -ALL BOLT LOCATIONS TO BE PRE-DRILLED.
- -NUTS ON GATE HARDWARE TO BE NON-REMOVABLE.
- -TOP RAIL OF RINK END BOARDS TO BE 2" x 4" RIPPED FROM 2" x 8" PRESSURE TREATED LUMBER.
- -ALL HARDWARE TO BE HOT-DIPPED GALVANIZED AFTER FABRICATION.
- -PLAYER'S BOXES TO BE CONSTRUCTED SEPARATELY FROM -NOTCH TOP PLATE OF RINK BOARDS TO FIT PLAYER'S BOX
- -FLOOR OF PLAYER'S BOXES TO BE NOTCHED AROUND STEEL POSTS. FLOOR TO BE FLUSH WITH BACK OF RINK

CHAIN LINK SCREENING

- -CHAIN LINK SCREENING SHALL BE LOCATED AT BOTH ENDS
- -ALL CHAIN LINK SCREENING TO BE 9 GAUGE STEEL WIRE WOVEN INTO 2" MESH. TOP & BOTTOM SELVAGE SHALL BE KNUCKLED.
- -TOP RAILS FOR SCREENING SHALL BE 1 1/2" DIAMETER. RAILS TO BE HAMMERED FLAT & WELDED TO
- -ALL WELDS TO BE SMOOTH & CONTINUOUS.
 -POSTS & RAILS TO BE CLEANED OF ALL WELDING RESIDUE. APPLY GALVALUME ACCORDING TO MANUFACTURER'S SPECIFICATIONS.
- -MESH TO BE ATTACHED TO UPRIGHTS WITH WIRE TIES AT 1'-0" O C
- -METAL STRAPPING TO BE INTERWOVEN IN MESH & SECURED TO TOP RAIL WITH SCREWS AT 8" O.C. STRAPPING TO BE CONTINUOUS POST TO POST.
- -CHAIN LINK SCREENING TO BE FLUSH WITH FRONT OF
- -CHAIN LINK CONSTRUCTION SHALL BE IN ACCORDANCE WITH CITY OF WINNIPEG STANDARD CONSTRUCTION SPECIFICATIONS CW 3550-R5.

GEO-TEXTILE FABRIC SPECIFICATIONS:

- 1. GEO-TEXTILE: SHALL CONSIST OF A WOVEN GEO-TEXTILE FABRIC, USED AS A SEPARATOR BETWEEN THE CRUSHED LIMESTONE SUB-BASE MATERIAL & THE COMPACTED SUB-GRADE. THE WOVEN GEO-TEXTILE MATERIAL FOR CONSTRUCTION SHALL BE MIRAFI 600X DISTRIBUTED BY ARMTEC, AMOCO 2006 DISTRIBUTED BY BROCK WHITE COMPANY, OR ARMTEC 855 BY ARMTEC
- ALL WORK RELATED TO THE GEO-TEXTILE STORAGE, HANDLING & INSTALLATION SHALL COMPLY WITH THE RECOMMENDATIONS OF THE MANUFACTURER
- PRIOR TO LAYING THE FABRIC, THE SUB-GRADE MATERIAL SHALL BE CLEARED OF ALL UNSUITABLE MATERIAL & COMPACTED TO PROVIDE A SMOOTH UNIFORM SURFACE.
- THE FABRIC SHALL BE EVENLY LAID IN ORDER TO ALLOW CONFORMITY TO THE COMPACTED SUB-GRADE. FOLDS & WRINKLES IN THE FABRIC SHALL BE AVOIDED. UPON COMPLETION OF THE INSTALLATION OF THE FABRIC, CRUSHED SUB-BASE MATERIAL SHALL BE INSTALLED.
- MATERIALS PLACED IN THIS PROJECT SHALL BE SUBJECT TO TESTING & APPROVAL BY THE CONTRACT ADMINISTRATOR. THE CONTRACT ADMINISTRATOR RESERVES THE RIGHT TO REJECT ANY MATERIALS OR WORK WHICH ARE NOT IN ACCORDANCE WITH THE REQUIREMENTS OF THIS SPECIFICATION.

PAINTING

INSIDE AND OUTSIDE OF RINK BOARDS NOT TO BE PAINTED BUT LEFT NATURAL P.T. WOOD. GAME LINES (RED AND BLUE) TO BE PAINTED ON BOARDS WITH 2 COATS OF PAINT APPLIED.

	THE CITY OF WINNIPEG PLANNING, PROPERTY AND DEVELOPMENT DEPARTMENT			SPECIFICATIONS		PROJECT	CC-064
Winnipeg						PARK CITY WEST COMMUNITY CENTRE	
Winnipeg		ICIPAL ACCOMMODA				OUTDOOR RINK REPLACEMENT	
	3-65	GARRY STREET, R30	C 4K4			115 SANFORD FLEMING ROAD	BID OPP#402-2019
DRAWN BY:		DESIGNED BY:	CHECKED BY:	APPROVED BY:	DATE:	SCALE:	SHEET No:
	JAW				2019.05.01	AS SHOWN	
					eFILE: 2017087V0.dwg	PROJECT No: 2019-047	Α/