



ISOLATED GROUND WIRING SCHEMATIC

## BILL OF MATERIALS AND INSTRUCTIONS

- 1 NEW ISOLATED GROUND DUPLEX RECEPTACLES (ORANGE COLOUR) 44 INCHES ABOVE FLOOR
- 2 INSULATED GROUND CONDUCTOR (GREEN YELLOW)
- 3 RIGID STEEL CONDUIT SUITABLE FOR GROUNDING
- (4) GROUND BUS ON INSULATORS: IF NOT PRESENT RUN INSULATED GROUND CONDUCTOR THROUGH TO TRANSFORMER NEUTRAL IN SAME CONDUIT AS PANEL FEEDER
- S POINT OF CONNECTION TO TRANSFORMER NEUTRAL
- (8) FLUORESCENT LIGHTING FIXTURES EXPLOSION PROOF, APPLETON NO. ARS232 WITH EFP248 GAURD MOUNTED HOZIZONTALLY
- The switch for pit lighting wire to 15A-1P Breaker in (12)
- 8 CO GAS DETECTOR TYPE RDS EXPLOSION PROOF
- BY CRITICAL ENVIRONMENTAL TECHNOLOGIES AVAILABLE THROUGH BPL SALES 10 NO GAS DETECTOR TYPE AST EXPLOSION PROOF
- 1 NO GAS DETECTOR/CONTROL PANEL TYPE SCP
- (2) EXISTING 120/208V, 36 PANEL WITH 15kVA TRANSFORMER ABOVE PANEL
- (3 2-15AMP, 1-POLE BREAKER IN (2)
- (4) #12−RW90

_	REVISED	Jan. 11/02	
_	ISSUED FOR FINAL REVIEW	Oct. 16/01	
_	ISSUED FOR TENDER	Aug. 24/01	
_	ISSUED FOR CLIENT REVIEW	July 10/01	
NO.	DESCRIPTION	DATE	BY

## REVISIONS

CITY OF WINNIPEG TRANSIT 421 OSBORNE ST., WINNIPEG MANITOBA

D.H. ROBBINS ENGINEERING CONSULTING STRUCTURAL ENGINEERS 3-430 River Avenue, Winnipeg, Manitoba, R3L 0C6

INSTALL FRONT END ALIGNMENT MACHINE DYNAMOMETER ROOM

ELECTRICAL AND MECHANICAL



M	MANENGCO EN 218 - 530 WINNIPEG. N R3H 0Y4	CENTURY STREET Tel (204) 783-0	757 778
DRN KMK	APP EPD		REV
CHK EPD	DATE 07/26/01	7 01154−M	1
1 GE	NERAL REVISION	08/13/01 KMK E	PD