

787-2019 ADDENDUM 2

FORT ROUGE GARAGE HOIST REPLACEMENT PROGRAM

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: 2019 September 04
BY: I. Minenkov
TELEPHONE NO. 204 943-7501

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

NMS SPECIFICATIONS

Replace: 03 30 00 – Cast In Place Concrete Rev 0 with 03 30 00 – Cast in Place Concrete R1.

Replace: 31 23 33 – Excavating, Trenching and Backfilling Rev 0 with 31 23 33 – Excavating, Trenching and Backfilling R1.

Section 41 22 23.23 In-Ground hoists

Revise: 2.1.1 to read: Acceptable Materials Manufacturers: Subject to compliance with requirements specified in this Section and as established by the Basis-of-Design Materials, manufacturers offering products that may be incorporated into the Work include; but are not limited to, the following:

- .1 Rotary 70Q-ALI
- .2 Stertil-Koni DIAMOND 64F (DIA64F)
- .3 or approved equal through a substitution approval request.

Revise: 2.2.1.4.3 to read: Lifts must be equipped with home pockets for saddles to sit flush with floor surface creating an unobstructed floor, free of tripping hazards. Alternatively, lifts must be equipped with home pocket for the rear saddle to sit flush with floor surface creating an unobstructed floor, free of tripping hazards and lifts must be equipped with a front saddle height that will accommodate a drive over clearance of 6 inches (152 mm).

DRAWINGS

Replace: 787-2019 _Drawing_E1.0 R0 with 787-2019 _Addendum_2 Drawing E1.0 R1.

787-2019 _Drawing_E1.1 R0 with 787-2019 _Addendum_2 Drawing E1.1 R1.

787-2019 _Drawing_E2.0 R0 with 787-2019 _Addendum_2 Drawing E2.0 R1.

787-2019 _Drawing_M1.0 R0 with 787-2019 _Addendum_2 Drawing M1.0 R1.

787-2019 _Drawing_M1.1 R0 with 787-2019 _Addendum_2 Drawing M1.1 R1.

787-2019 _Drawing_S0.1 R0 with 787-2019 _Addendum_2 Drawing S0.1 R1.

787-2019 _Drawing_S2.1 R0 with 787-2019 _Addendum_2 Drawing S2.1 R1.

787-2019 _Drawing_S2.2 R0 with 787-2019 _Addendum_2 Drawing S2.2 R1.

787-2019 _Drawing_S2.3 R0 with 787-2019 _Addendum_2 Drawing S2.3 R1.

787-2019 _Drawing_S4.1 R0 with 787-2019 _Addendum_2 Drawing S4.1 R1.

787-2019 _Drawing_S4.2 R0 with 787-2019 _Addendum_2 Drawing S4.2 R1.

787-2019 _Drawing_S4.3 R0 with 787-2019 _Addendum_2 Drawing S4.3 R1.