



793-2019 ADDENDUM 2

SPRINKLER SYSTEM EXTENSION TO ORIGINAL BUILDING ATTIC AT DAKOTA COMMUNITY CENTRE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
TENDER**

ISSUED: October 3, 2019
BY: Jason Wiebe
TELEPHONE NO. 204 770-0245

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE TENDER AND SHALL FORM A PART
OF THE CONTRACT DOCUMENTS**

Template Version: A20190115

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

- | | | |
|------|----------|---|
| Add: | D2.2 (m) | Replace two (2) existing wet upright sprinklers in entrance vestibule with dry sidewall sprinklers. |
| Add: | D2.2 (n) | Contractor to cut three (3) access holes 3' x 3' into existing attic space to accommodate installation of sprinkler piping. Install new Babcock Davis Exterior Access Doors Model BXT/BXP to close off attic space. Colour to match existing wall finish. |