



24-2020 ADDENDUM 4

Sherwin Road Reconstruction and Culvert Replacement over Omand's Creek

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE TENDER

ISSUED: August 7, 2020
BY: Bill Ebenspanger
TELEPHONE NO. 204 977-8370

THIS ADDENDUM SHALL BE INCORPORATED INTO THE TENDER AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20190115

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, **August 13, 2020**.

PART D – SUPPLEMENTAL CONDITIONS

Add: D30.4: The following standpipe piezometer readings and creek water levels have been measured at the Site:

DATE	STANDPIPE PIEZOMETER READINGS (ELEV.) (m)	OMAND'S CREEK WATER LEVEL (ELEV.) (m)
2019-09-11	232.67	-
2019-10-28	232.65	-
2019-10-29	-	232.99
2020-03-31	-	233.71
2020-04-13	-	233.37
2020-05-11	232.48	232.52
2020-08-07	232.26	232.65