



**393-2020  
BRADY ROAD LANDFILL  
STANDBY GENERATOR  
ADDENDUM 01**

**URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
TENDER**

ISSUED: June 12, 2020  
BY: Paul Lapointe, KGS Group  
TELEPHONE NO. 204-896-1209

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE TENDER AND SHALL FORM A PART  
OF THE CONTRACT DOCUMENTS**

Template Version: A20160708

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

---

**APPENDICES**

Add: Appendix\_A Contractor walk-thru attendee list

**QUESTIONS AND ANSWERS**

- Q1: We will take deviation to providing a splitter inside of the weatherproof generator enclosure. We will provide dual breakers (1 x 225A 3P paralleling breaker as Gen Main breaker and 1 x 225A 3P breaker as Load Bank breaker) connected to alternator directly. Please advise acceptance
- A1: This is an acceptable approach however further review of the wiring method within the generator enclosure will need to take place during the shop drawing review period.
- Q2: Is a manual bypass switch required?
- A2: Yes, a manual bypass switch is required per the specifications.
- Q3: Will it be acceptable to provide 5-gallon spill containment box in lieu of fill limited valve? Is electronic level transmitter required?
- A3: Fill limiter valve to be provided. Electronic level transmitter is required.
- Q4: Is a 10-year warranty required for the genset as 5 year is the normal?
- A4: 10 year warranty to be provided.

## **Appendix A – Contractor Walk-Thru Attendee List**

The following is a list of attendees at the on-site walk-thru on June 9th, 2020.

<b><u>Name</u></b>	<b><u>Company</u></b>	<b><u>Email</u></b>
John Hirst	Oak Park Powerline	<a href="mailto:john@oakparkpowerline.com">john@oakparkpowerline.com</a>
Josh Wuirch	Advance Services Group	<a href="mailto:josh@advanceservices.ca">josh@advanceservices.ca</a>
Brett Shorrock	ABCO Supply	<a href="mailto:brett.shorrock@abcosupply.com">brett.shorrock@abcosupply.com</a>
Jason Mallin	G.Mallin Electric	<a href="mailto:jason@gmallinelectric.com">jason@gmallinelectric.com</a>
Kevin Blunden	EXCO Electric	<a href="mailto:kevinb@excoelectric.com">kevinb@excoelectric.com</a>
Kevin Mireault	AAA Electric	<a href="mailto:kevin@aaaelectric.ca">kevin@aaaelectric.ca</a>
Arron McKnight	TMJC	<a href="mailto:amcknight@tmlgroup.com">amcknight@tmlgroup.com</a>
Gino Gilberto	Shermco	<a href="mailto:ggilberto@shermco.com">ggilberto@shermco.com</a>
Chad Stefiuk	Electric 2000	<a href="mailto:chad@electric2000.ca">chad@electric2000.ca</a>
Ryan McDonald	Nor-Tec Group	<a href="mailto:rmcdonald@nortecgroup.com">rmcdonald@nortecgroup.com</a>
Dave Breen	NRG Management	<a href="mailto:industrial@nrgmgmt.ca">industrial@nrgmgmt.ca</a>