



799-2020 ADDENDUM 1

SUPPLY AND DELIVERY OF FORCE MAIN PIPE – BALTIMORE FORCE MAIN CROSSING

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE TENDER

ISSUED: December 10, 2020
BY: Kimberly Yathon
TELEPHONE NO. 204 986-6880

THIS ADDENDUM SHALL BE INCORPORATED INTO THE TENDER AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20190115

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Delete: E4.2.1(e)

Revise: E4.4.3(a) to read: Force main pipe shall be Schedule 80S (0.500 wall thickness), seamless, stainless steel pipe to conform to the requirements of ASTM A312 Grade TP304L.