

91-2020 ADDENDUM 4

NORBERRY-GLENLEE COMMUNITY CENTRE PLAYGROUND DEVELOPMENT

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE REQUEST FOR PROPOSAL

ISSUED: March 2/20
BY: Lindsay Lagman
TELEPHONE NO. 204 – 451-4185

THIS ADDENDUM SHALL BE INCORPORATED INTO THE REQUEST FOR PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: Ar20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Proposal may render your Proposal non-responsive.

PART E – SPECIFICATIONS

Revise: E11.6.2 to read: Materials

- (a) Base course shall be Granular C as per current CW 3110, the Drawings, and this Specification.
 - (i) Notwithstanding current CW 3110 Section 1.2 Clause 1.2.7, Granular A, Granular B, and recycled aggregates or materials will not be accepted for Compacted Granular Pathways.
- (b) Topping Material shall be per the Drawings and this Specification.
 - (i) Recycled aggregates or materials will not be accepted for Compacted Granular Pathways.

Table 1.0 Base Course & Topping Material Grading Requirements

CANADIAN METRIC SIEVE SIZE	Percent of Total Dry Weight Passing Each Sieve		
	6 mm (1.4") Topping Material	20 mm (3/4") Base Course	50 mm (2") Base Course
50 000	--	--	100%
25 000	--	--	--
20 000	--	100%	--
10 000	100%	--	--
5 000	65% - 100%	40% - 70%	25% - 60%
2 500	40% - 75%	25% - 60%	--
1 250	35% - 65%	--	--
630	19% - 36%	--	--
315	14% - 28%	8% - 25%	--
160	12% - 24%	--	--
80	10% - 25%	6% - 17%	4% - 15%