



276-2021 ADDENDUM 1

KEEWATIN UNDERPASS PUMPING STATION – 2021 UPGRADES

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE TENDER

ISSUED: 2021-06-02
BY: Brian Cleven
TELEPHONE NO. 204 786-8080

THIS ADDENDUM SHALL BE INCORPORATED INTO THE TENDER AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20190115

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E19.2.5 to read: Provide **Schedule 40 PVC** drainage piping system from pump seal water leakage connections and backflow preventer drain to the wet well as shown on the drawings.

DRAWINGS

Replace: 276-2021_Drawing_1-0304U-E0004-001-00 with 276-2021_Addendum_1_Drawing_1-0304U-E0004-001-0A

Replace: 276-2021_Drawing_1-0304U-E0009-001-00 with 276-2021_Addendum_1_Drawing_1-0304U-E0009-001-0A

NMS SPECIFICATIONS

Revise: 07 61 00 clause 2.2.1 to read: Self-adhesive, modified bitumen sheet, minimum 1 mm (40 mils) thick, non-slip surface. Acceptable material: IKO Armour Gard Ice and Water Protector, W.R. Grace Ice and Water Shield; Domtar Eavesshield; Nordshield Water Stopper; Bakor/**Henry** Eave Guard; BPCO ProGard; EMCO Gripgard, **Bakor/Henry WP200, WR Meadows Mel-Rol**, or approved equal in accordance with B7.

Revise: 23 33 15 clause 2.1.11 to read: Acceptable materials: Tamco 9000SC, **Alumavent**, or approved equal in accordance with B7.

Revise: 23 33 15 clause 2.2.11 to read: Acceptable materials: Tamco 1000, **Alumavent**, or approved equal in accordance with B7.

Revise: 23 41 00 clause 2.3.6 to read: Acceptable material: Camfil Farr 30/30, **AAF/Flanders**, or approved equal in accordance with B7.

Revise: 26 28 21 clause 2.5.1.2 to read: Sensor Rating: **250A**

Revise: 26 28 21 clause 2.5.1.3 to read: Trip Unit Type: Electronic **LSI**, Factory Sealed

- Revise: 26 28 21 clause 2.5.1.4 to read: Long Time PU: **70A – 250A**
- Revise: 26 28 21 clause 2.5.1.5 to read: Long Time Delay: **Non-Adjustable**
- Revise: 26 28 21 clause 2.5.1.6 to read: Short Time PU: **1.5 – 10 x Sensor Rating**
- Revise: 26 28 21 clause 2.5.1.7 to read: Short Time Delay: **Non-Adjustable**
- Revise: 26 28 21 clause 2.5.1.8 to read: Instantaneous: **1.5 – 12**
- Revise: 26 28 21 clause 2.5.1.10 to read: Model: Schneider Electric PowerPact **J** series with Micrologic 3.2**S** series trip unit, or approved equal in accordance with B7.
- Revise: 26 32 10 clause 2.2.A to read: The engine shall be a stationary, liquid cooled, 150 kW, 60 Hz, 1,800 rpm, four-cycle design, vertical inline or V-type, with dry exhaust manifolds. It shall have **minimum** six (6) cylinders with minimum total displacement of **8.8** liters and be manufactured in the United States or Canada.
- Revise: 26 32 10 clause 2.2.O to read: Acceptable manufacturers:
1. Generac,
2. Caterpillar (CAT),
3. Or approved equal in accordance with B7.
- Revise: 33 41 01 clause 2.1.15.9 to read: Motors shall be capable of **six (6)** starts per hour on a continuous basis without temperature rise that could damage the motor.
- Add: 33 41 01 clause 2.1.15.12: Efficiency: Premium.
- Delete: 33 41 01 clause 2.1.17.2.1
- Delete: 33 41 01 clause 2.1.17.2.2
- Delete: 33 41 01 clause 2.1.17.2.5