



## 31-2021 ADDENDUM 02

### RON DUHAMEL TENNIS COURT CONSTRUCTION

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
BID/PROPOSAL**

ISSUED: March 9, 2021  
BY: Courtney Klassen  
TELEPHONE NO. 204 451-2723

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID/PROPOSAL AND SHALL FORM  
A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20190115

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

#### **PART E – SPECIFICATIONS**

- Revise: E13.1.1(a) to read: Asphaltic Concrete shall be supplied and installed in accordance with City of Winnipeg Standard Construction Specification CW 3410, **CW 3130 and CW 3135**.
- Add: E13.1.2(b): Geotextile shall be non-woven and installed as shown on the drawings. It shall have an apparent opening size of between 0.149 mm and .210 mm and a minimum unit weight of 135 grams per sq. m.
- Add: E13.1.2(c): Geogrid shall be Class B and installed as shown on the drawings and as per CW 3135.
- Revise: E17.2.4(a): Tache Backless Bench Composite **with arms**
- Revise: E17.2.4(a)(i): Product Number: **52501071GLV**
- Revise: E17.2.4(a)(iii): Specification:  
**SCD-121C**

#### **DRAWINGS**

- Add Drawing: 31-2021\_Addendum\_02\_Drawing\_SCD-121C-R3