



324-2021 ADDENDUM 3

2021 SEWER RENWEALS BY CIPP LINING – CONTRACT 2

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: June 4, 2021
BY: Nathan Kehler, P. Eng.
TELEPHONE NO. 204-792-6002

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART E – SPECIFICATIONS

- Add: E7.3 (i): The Contractor shall demonstrate that the installed flow bypass system operates as intended, and is capable of conveying the incoming flows prior to lining.
- Add: E7.3.1 (l): Storage in the upstream system will be limited to the obvert of the pipe immediately upstream of any manhole being used for pumping. Upstream storage as a means of buffering incoming flows is not an acceptable method of flow control.