

434-2021 ADDENDUM 1

PROFESSIONAL CONSULTING SERVICES FOR PORTAGE AVENUE INTERCEPTOR SIPHON REPLACEMENT AT OMAND'S CREEK

ISSUED: June 28, 2021 BY: Duane Baker TELEPHONE NO. 204 986-4289

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID/PROPOSAL

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID/PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B - BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, **July 2**, 2021.

<u>APPENDICES</u>

Replace: 434-2021 Appendix B – Additional Information with 434-2021 Addendum 1-Appendix B – Additional Information

The following is a summary of the change:

Added - Drawing - U200-95-18 Wingwall Extensions - Piling Layouts and Foundation Plans

QUESTIONS AND ANSWERS

Q1: Is there any geotechnical information available in the area of the siphon? If not, should we budget to drill a hole on each side of the creek to confirm if trenchless is feasible?

A1: There is an Engineer's report regarding the geotechnical investigations as part of the previous overpass culvert project but we are unable to obtain a copy at this time. The record drawings provided in Appendix B of the Request for Proposal (RFP) state that the new 350 PVC watermain was augered, suggesting that trenchless is feasible. If upon the award of the RFP it is determined that test holes are required, we will issue a contract change for the work.

Q2: Is the existing siphon a component of an existing Environment Act License? If so, can the City provide that Environment Act License?

A2: This siphon falls under the license here: https://www.gov.mb.ca/sd/eal/registries/1071.1/index.html