



442-2021B ADDENDUM 6

CONSTRUCTION OF THE NORTH DISTRICT POLICE STATION AT 100 SINCLAIR STREET

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID/PROPOSAL

ISSUED: May 30, 2022
BY: Marnie Gartrell, MAA
TELEPHONE NO. 204 942 0981

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID/PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, June 2, 2022.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D14.4 to read: The City intends to award this Contract by July 29, 2022.

DRAWINGS

Replace: 442-2021B_Drawing_ A2.1 with Addendum_6_442-2021B_Drawing_ A2.1-R7.
442-2021B_Drawing_ A2.2 with Addendum_6_442-2021B_Drawing_ A2.2-R6.

NMS SPECIFICATIONS

Section 01 21 13 Allowances

Delete:	1.3.9:	.9	Building Envelop Testing, Refer to Sections 07 08 00 and 08 08 00.
		.1	Amount of Cash Allowance \$15,000.00
Revise:	1.3.6 to read:	.6	Building Envelop Testing, Refer to Sections 07 08 00 and 08 08 00.
		.1	Amount of Cash Allowance \$15,000.00

Section 08 80 00 Glazing

- Revise: 2.1.5 to read: .5 Glass (Type E): Ballistic resistant glass-clad polycarbonate, Thickness: 17mm.
.1 Acceptable Manufacturer:
.1 Prelco, Prel-Secur.
- Revise: 2.2.3 to read: .3 Sealed Insulating Glass (SG-3): Not Used.