

- B. THIS BUILDING MAY CONTAIN ASBESTOS. REFER TO FRONT END
- THE CITY AS REQUIRED.

## DEMOLITION KEY NOTES #

- 3. DEMOLISH, REMOVE AND RELOCATE EXISTING INTAKE. REPAIR AND SEAL ROOF OPENING. REFER TO STRUCTURAL AND ROOFING
- 4. DEMOLISH, REMOVE AND RELOCATE EXISTING EXHAUST OUTLET. REPAIR AND SEAL ROOF OPENING. REFER TO STRUCTURAL AND
- 5. DEMOLISH, REMOVE AND RELOCATE EXISTING CONDENSING UNIT. EXTEND REFRIGERANT PIPING OR UPSIZE AS REQUIRED. RECHARGE REFRIGERANT AFTER RE-INSTALLATION.
- 6. EXISTING COMPRESS AIR INTAKE/EXHAUST TO REMAIN.
- 8. EXISTING INTAKE TO REMAIN.
- PATCH WALL OPENING TO MATCH ADJACENT CONDITION AND
- 11. EXISTING EXHAUST FAN AND DUCT TO BE COMPLETELY REMOVED BACK TO WALL PENETRATION.



- A. ALL ABANDONED EQUIPMENT AND SERVICES WITHIN AREA OF WORK SHALL BE REMOVED.
- SPECIFICATIONS FOR FURTHER INFORMATION.
- C. PRIOR TO DEMOLISHING AND REMOVAL OF THE EXISTING EQUIPMENT. COORDINATE WITH THE CITY. RETURN EQUIPMENT TO
- D. FOR DRAWING CLARITY, NOT ALL MECHANICAL EQUIPMENT, PIPING AND DUCTWORK HAS BEEN SHOWN.




\_AREA OF


WORK

DEMOLISH AND REMOVE EXISTING MUAS AND ASSOCIATED DUCTWORK, VENTING AND INTAKE. REPAIR AND SEAL ROOF OPENING. REFER TO STRUCTURAL AND ROOFING SPECIFICATION/DETAILS.

- 2. DEMOLISH AND REMOVE EXISTING EXHAUST FAN DUCTWORK. REPAIR AND SEAL ROOF OPENING. REFER TO STRUCTURAL AND ROOFING SPECIFICATION/DETAILS.
- SPECIFICATION/DETAILS.
- ROOFING SPECIFICATION/DETAILS.
- 7. EXISTING EXHAUST FAN TO REMAIN.
- 9. EXISTING CONDENSING UNIT TO REMAIN.
- 10. REMOVE EXISTING GOOSENECK DUCT SUPPORT ON THE WALL.



ENGINEERS GEOSCIENTISTS MANITOBA Certificate of Authorization SMS Engineering Ltd. No. 166



J. T. HORROCKS Member 24767



Project Title

TRANSIT MAINTENANCE AND REPAIR BUILDING MECHANICAL **UPGRADE - WEST HIGH BAY** WINNIPEG MANITOBA

PARTIAL ROOF PLAN -**VENTILATION - DEMOLITION** 

Drawn By	Checked By	Approved By
RNS	XZ	JH
Scale 1/16"=1'-0"	Date JUNE 2022	Project No. 20-349-01
Revision Number	Drawing Number	Sheet Order
0	M1.5	5 OF 10