



- 1 ELECTRICAL CONTRACTOR TO REFER TO ARCHITECTURAL DRAWINGS FOR INSTALL LOCATIONS OF LIGHT FIXTURES.
- INTERLOCK EMERGENCY LIGHTING WITH LIGHT CIRCUIT IN AREA OF SERVICE.
- SUPPLY & INSTALL 3/4" THICKNESS BACKING FOR POT LIGHT TO EXTEND AT LEAST A MINIMUM OF 12" IN ALL DIRECTIONS. BACKING TO BE PLYWOOD, HARDIBOARD OR EQUIVALENT MATERIAL.
- 4 SUPPLY & INSTALL STAINLESS STEEL SECURITY HARDWARE FOR ALL LIGHT FIXTURES & CAGES WITHIN 10' OF FFL OR FGL.
- 5 SUPPLY & INSTALL EXPOSED ELECTRICAL TO BE IN EMT. PAINT ALL EMT ELECTRICAL INSTALLATION TO MATCH EXISTING FINISH & COLOR SPECIFIED ON ARCHITECTURAL DRAWINGS.

SWITCH SCHEDULE		
CALLOUT	SYMBOL	NOTE 1
CO Switch	\$ <sub>80</sub>	LEVITON, PART#VPOSR-10 FOR WIRING TO PART# VPT24-1PZ. FULLY PROGRAM & SETUP.
os	\$ 8	LEVITON, PART#OSSMIT—MDW, ADJUST BLINDS TO PREVENT EXTENDED ACTIVATION
TIME-LOCK Switch	\$ <sub>TA</sub>	LEVITON, PART# VPT24—1PZ. FULLY PROGRAM & SETUP. IF LOAD EXCEEDS 80% OF TIME LOCK CAPACITY USE CONTACTOR TO CONTROL CIRCUIT

IBASA Electrical Engineering Design & Consulting

490 Paul Blvd. Winnipeg, MB R2N 4C8 T. 204-515-1158 info@ibasa.ca www.ibasa.ca COPY RIGHT RESERVED:
THE CONTRACTOR SHALL VERIFY AND BE
RESPONSIBLE FOR ALL DIMENSIONS. DO
NOT SCALE THE DRAWING — ANY ERRORS
OR OMISSIONS SHALL BE REPORTED TO
BIASA ENTERPRISES INC.
THE COPYRIGHTS TO ALL DESIGNS AND
DRAWINGS ARE THE PROPERTY OF IBASA
ENTERPRISES INC. REPRODUCTION OR
USE FOR ANY PURPOSE OTHER THAN
THAT AUTHORIZED BY IBASA ENTERPRISES
INC. IS FORBIDDEN.





CLIENT: BRIDGMAN COLLABORATIVE ARCHITECTURE
678 MAIN STREET
WINNIPEG, MB R3B 1E4
(204)488-3857

OJECT TITLE: LOO LOO WINNIPEG
715 MAIN ST., WINNIPEG, MB
BID OPPORTUNITY 54-2021

MAIN LEVEL—LIGHTING LAYOUT

SHEET NO:

PROJECT NO: DESIGNED BY: AK DRAWN BY: AK REVIEWED BY: AK

E02.2