



# 559-2021 ADDENDUM 3

## LINDEN LIFT AND FLOOD PUMPING STATION (LFPS) UPGRADES

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
BID/PROPOSAL**

ISSUED: September 16, 2021  
BY: Carlos Mota  
TELEPHONE NO. 204 954-6884

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID/PROPOSAL AND SHALL FORM  
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

### **NMS SPECIFICATIONS**

Specification 25 30 01 – Control Panels,

Revise 2.4.2 - Acceptable panel manufacturer shall be Indus Automation, Manco Control Systems Inc., Celco Controls, Tri-Star Automation Inc., or approved equal.

Specification 25 30 02 – Instruments, Add:

#### **2.7 SEAL WATER PRESSURE SWITCH, PSL-F526**

.1 Requirements:

- .1 Pressure Range: 0 to 100 PSI (adjustable).
- .2 Service: Domestic Water.
- .3 Enclosure Rating: NEMA Type 4X
- .4 Output: Qty 1, SPDT dry contact, 10A at 125 VDC.
- .5 Electrical Connection: ½" NPT (female).
- .6 Process Connection: ¼" NPT (female).
- .7 Mounting: Pipe.
- .8 Approvals: CSA and/or cUL.

.2 Acceptable Products:

- .1 Ashcroft B4 Series or approved equal.

#### **2.8 FLOOD STATION GATE SWITCH, ZS-F901**

- .1 Provide gate position contact switch to monitor "Open / Close" status of the flood station gate.
  - .1 Enclosure rating:
  - .2 Category 2 corrosive environment.

- .3 Output: One (1) Form "C" dry contact for digital input to PLC.
- .4 Acceptable manufacturer shall be Emerson Model 7C GO™ Switch / 7CX, Turck BI1 Series.

## **QUESTIONS AND ANSWERS**

The questions below are written as received from bidders:

Q1: Drawing A0001 shows PSL-F526 pressure switch but we can't seem to find the specifications for this filed device. Can you please provide the specifications for this?

A1: See Specification 25 30 02 Section 2.7.

Q2: Drawing A0001 shows ZS-F901 position switch but we can't seem to find the specifications for this filed device. Can you please provide the specifications for this?

A2: See Specification 25 30 02 Section 2.8.

Add the following field device to Appendix C – Instrument List:

NEW / ZS-F901 / FLOOD STATION GATE CONTACT SWITCH / FLOOD STATION DRY WELL / 25 30 02 / 1-0155L-A0001-001 / 1-0155L-P0002-001 / 1-0155L-A0012-001 / PIPE / 6 - AUTOMATION

Q3: Drawing A0001 shows XV-010 and XV-020. On Drawing M0004 listed SV-010 and SV-020. Can you please clarify if XV-010 and SV-010 are the same single instrument? Can you please also clarify if XV-020 and SV-020 are the same single instrument? If XV-010 and SV-010 are not the same and XV-020 and SV-020 are also not the same, can you please provide the specifications for the XV-010 and XV-020?

A3: These refer to the same instruments. The correct tags are XV-010 and XV-020. SV-010 and SV-020 are typos.

Q4: Drawing A0001 shows FSL-010 and FSL-020. On Drawing M0004 listed FSL-011 and FSL-021. Can you please clarify if FSL-010 and FSL-011 are the same single instrument? Can you please also clarify if FSL-020 and FSL-021 are the same single instrument? If FSL-010 and FSL-011 are not the same and FSL-020 and FSL-021 are also not the same, can you please provide the specifications for the FSL-010 and FSL-020?

A4: These refer to the same instruments. The correct tags are FSL-010 & FSL-020. FSL-011 & FSL-021 are typos.

Q5: Addendum 1 Instrument List listed TT-A910 which referenced to Drawing A0001 but Drawing A0001 shows TE-A690 (which has a transmitter of TT-A690 (tag shown on Drawing A0014). Can you please clarify that TT-A910 is a typo and it should be TT-A690?

A5: These refer to the same instrument. The correct tag is TT-A910. TE-A690 and TT-A690 are typos.

Q6: Please provide specifications for the temperature transmitter TT-A910 and/or TT-A690?

A6: HVAC controls temperature devices are specified in Section 23 09 93 – HVAC Controls, Clause 2.6.

Q7: The drawings are calling for thermal insulation c/w aluminum cladding on the outside air hoods on the exterior of the building. This is uncommon and would serve no purpose. Can you confirm if this is correct?

A7: Delete the thermal insulation indicated on the Mechanical drawings and Drawing P0005 on the outdoor air intake hoods.

Q8: Question concerning the ground grid: The ground wire inside the building that all of the equipment bonds to does not have a size specified. Neither does the ground wire from the CSTE to the ground rods. Only size

mentioned is for a “ground ring 1#500 bare” shown in the detail drawing. Does this mean that a #500MCM bare wire is to be installed from the ground rods thru the CSTE then around the inside of the building?

A8: Refer to Electrical Drawing E0007 – Grounding Installation Details

- Grounding conductor from grounding grid to CSTE to be #2/0 (bare)
- Ground conductor from CSTE into building to be #2/0.
- Ground conductor to JB-A72-GEN to be #2.
- Revise ground conductors to cable tray and flood pumps P-F01 & P-F02 from #2/0 to #2.

### **APPROVED EQUALS**

The following have been requested to be approved equals for this project. Bidders shall ensure that products selected for this project meet or exceed specified material and performance requirements:

Specification	Item	Specified Product	Requested Equal	Equal Granted?
25 30 01	Control Panels	Indus Automation, Manco Control Systems Inc., Celco Controls	Tri-Star Automation Inc.	Yes