



896-2021 ADDENDUM 02

NEWPCC UV TRANSFORMER REPAIR

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: January 26, 2022
BY: Curtis Reimer
TELEPHONE NO. 431-337-0181

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

QUESTIONS AND ANSWERS

Q1: What method of cable testing is required? Is VLF (Very Low Frequency) testing required for the cables?

A1: The Contractor is responsible for the cable testing in accordance with 26 08 05. For medium voltage cables, the applicable section is Section 3.9 of 26 08 05. VLF (Very Low Frequency) testing is **not** specified. Insulation resistance testing of medium voltage cables will be performed with 2500 VDC for a duration of one minute (as specified).