



## 896-2021 ADDENDUM 03

### NEWPCC UV TRANSFORMER REPAIR

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
BID/PROPOSAL**

ISSUED: February 2, 2022  
BY: Curtis Reimer  
TELEPHONE NO. 431-337-0181

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID/PROPOSAL AND SHALL FORM  
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

#### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, February 7, 2022.

#### **NMS SPECIFICATIONS**

Section 26 12 16 DRY-TYPE, MEDIUM-VOLTAGE TRANSFORMERS

- Add: 1.4.4 Paint system to utilize an epoxy primer, designed to be utilized with the paint system over existing paint.
- Add: 1.4.5 Remove all corrosion prior to painting. Utilize a wire brush or similar abrasive tool system that will not damage the transformer within the enclosure.
- Add: 1.4.6 Clean the transformer prior to painting.

#### **QUESTIONS AND ANSWERS**

Q1: Is sandblasting required for the four (4) transformers?

A1: No, sandblasting is not appropriate for the transformer enclosures due to the risk of damaging the transformers within. Utilize a wire brush or abrasive system that does not risk damage to the transformers within.