


**GENERAL NOTES:** 

...

## **KEYNOTES:**

COORDINATE ROUTING OF CABLE ON SITE. CABLE SHALL BE INSTALLED ON CABLE TRAY LOCATED IN THE LOWER LEVEL. PROVIDE CORING ON EXISTING FLOOR AS REQUIRED AND SEAL.

PROVIDE NEW MCB, 50A-3P, 600V CIRCUIT BREAKER C/W FVNR STARTER WITH RED PILOT LIGHT RUN INDICATOR IN EXISTING MCC-1WB.





B.M. ELEV.  CONSTRUCTION COMPLETION DATE: YYYY MM DD				KGS			ENGINEER'S SEAL
				DESIGNED BY		CHECKED BY	
				DRAWN BY	RG	APPROVED BY	
1 0 NO.		2022 07 05 2022 05 18		SCALE:	AS SHOWN	RELEASED FOR CONSTRUCTION  DATE	CONSULTANT DRAWING NUMBER  21-0107-015_E2.403

PLOT DATE: 2022 07 12



THE CITY OF WINNIPEG

SHEET 1 OF 1

WATER AND WASTE DEPARTMENT ENGINEERING DIVISION

NORTH END SEWAGE TREATMENT PLANT (NEWPCC)
INTERIM PHOSPHOROUS REMOVAL
AUTOMATION

DEWATERING BUILDING SECOND FLOOR COMPRESSOR

BID OPPORTUNITY: 197-2022 FILE PATH: \\192.168.0.226\r-dat CONTRACT NUMBER: FILE NAME: 1-0101-EGAD-F206-0