

225-2022 ADDENDUM 1

WHYTE RIDGE COMMUNITY CENTRE SPRAY PAD

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID/PROPOSAL

ISSUED: March 18, 2022 BY: Dean Spearman TELEPHONE NO. 204-261-4137

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID/PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

FORM B: PRICES

Replace: 225-2021_Form_B-Prices with 225-2022_Addendum_1-Form_B-Prices. The following is a summary of changes incorporated in the replacement Bid/Proposal Submission:

File name has changed and now has the correct project number.

PART E – SPECIFICATIONS

Revise: E26.8 (a) to read: (a) Contractor shall pour a 10 cm thick concrete pad measuring 1600 mm x 2450

mm so that the top of the pad is flush with the adjacent finish surface and anchor the

Accessible table by bolting it to the concrete pad.

Revise: E26.9 (a) to read: (a) Contractor shall pour a 10 cm thick concrete pad measuring 1600 mm x 2450

mm so that the top of the pad is flush with the adjacent finish surface and anchor the

Accessible table by bolting it to the concrete pad.

DRAWINGS

Replace: 225-2022 Drawing C-1-R2 with 225-2022 Drawing C-1-R3

QUESTIONS AND ANSWERS

Q1: Will the 2" water meter be supplied by the City? I see a comment that states the water meter and flanges will be supplied, however, I see another section that suggests water meter is contractors responsibility.

A1: Water meter will be supplied by City. Contractor is responsible for all other work (e.g. back-flo, meter pit).