



NOTES:

1. DISCONNECT EXISTING MAIN UNDERGROUND FEEDER. FEEDER RUNS UNDER RAMP AND SHALL BE ABANDONED.
2. EXISTING MAIN DISTRIBUTION SHALL REMAIN IN EXISTING ELECTRICAL ROOM IN THE BASEMENT AND SHALL BE RE-LABELLED AS SD-1.
3. DISCONNECT AND REMOVE EXISTING CONDENSING UNIT IN THIS LOCATION.
4. DISCONNECT EXISTING CONDENSING UNIT AT THIS LOCATION AND RELOCATE TO NEW LOCATION SHOWN. WIRE AND CONNECT TO EXISTING BREAKER.



No.	Date	Issue / Revision	By
2	JULY 13, 2022	ISSUED FOR ADD#06	
1	JUNE 21, 2022	ISSUED FOR CONSTRUCTION	DG

Drawn By: MFP
Printing Date:

Drawings and specifications, as instruments of service are the property of the architects, the copyright in the same being reserved to them. No reproduction may be made without the permission of the architects, and when made, must bear their names. All prints to be returned.

The contractor is to verify dimensions and data noted herein with conditions on the site and is held responsible for reporting any discrepancy to the architects for adjustment.



**CITY OF WINNIPEG
BONIVITAL POOL RENEWAL**

1215 Archibald St, Winnipeg, MB.

**SITE PLAN
ELECTRICAL**

1 SITE PLAN ELECTRICAL
E1.1 SCALE: 1:100