



- NOTES:**
1. DISCONNECT EXISTING MECHANICAL EQUIPMENT AND REMOVE ALL EXISTING WIRING AND CONDUIT.
 2. EXISTING DEVICES IN BASEMENT TO REMAIN AND BE MAINTAINED.
 3. REPLACE EXISTING EXIT SIGN WITH NEW RUNNING MAN EXIT SIGN.
 4. DISCONNECT EXISTING METER.
 5. EXISTING DISTRIBUTION MD-1 SHALL BE RELABELLED SD-1 AND SHALL BE FED FROM NEW TRANSFORMER.
 6. MECHANICAL CONTROL AND SECURITY CONTROL SHARE A CABINET. EXISTING CONTROLS FOR SAME SHALL REMAIN IN CABINET AND BE MAINTAINED.
 7. DISCONNECT ANY ELECTRICAL FOR CONTROL PANEL FOR EXISTING BOILERS BEING REMOVED AND RE-USE THE EXISTING CIRCUIT TO FEED NEW BOILER CONTROLS.
 8. EXISTING FIRE ALARM CONTROL PANEL SHALL BE REPLACED WITH NEW. PROVIDE NEW ANNUNCIATOR IN VEST. SEE NEW WORK.

ENGINEERS
GEOSCIENTISTS
MANITOBA
Certificate of Authorization
MCW Consultants Ltd.
No. 7183

MCW
13600
210-821 Wellington Avenue
Winnipeg, Manitoba, R3M 0G4
Phone: (204) 779-7900
Fax: (204) 779-7900
www.mcw.com
MCW Consultants Ltd.

2	JULY 13, 2022	ISSUED FOR ADD#06	
1	JUNE 21, 2022	ISSUED FOR CONSTRUCTION	DG
No.	Date	Issue / Revision	By

Drawn By:
Printing Date:

Drawings and specifications, as instruments of service are the property of the architects, the copyright in the same being reserved to them. No reproduction may be made without the permission of the architects, and when made, must bear their names. All prints to be returned.

The contractor is to verify dimensions and data noted herein with conditions on the site and is held responsible for reporting any discrepancy to the architects for adjustment.

LM LM Architectural Group
500-136 Market Ave
Winnipeg, Manitoba, Canada R3B 0P4
t: (204) 942.0681 f: (204) 943.8676
www.lm-architects.com

**CITY OF WINNIPEG
BONIVITAL POOL RENEWAL**

1215 Archibald St, Winnipeg, MB.

**BASEMENT FLOOR PLAN
DEMOLITION
ELECTRICAL**

1 BASEMENT FLOOR PLAN DEMOLITION ELECTRICAL
ED2.0 SCALE: 1:100