



718-2022 ADDENDUM 2

RIVERBEND LIFT STATION UPGRADES

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID/PROPOSAL

ISSUED: August 3, 2023
BY: Blair Moore
TELEPHONE NO. 204 453-2301

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID/PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B – BIDDING PROCEDURES

Add: B3.5 The Contract Administrator will be available at the Site at Riverbend Lift Station located at 1740 Portage Avenue from 10:30 p.m. to 11:30 p.m. on August 9, 2023 to provide Bidders access to the Site.

PART D – SUPPLEMENTAL CONDITIONS

- Revise: D18.1(a) to read: The two (2) new pumping units must be put into fully automated service by June 15, 2024.
- Revise: D19.1 to read: The Contractor shall achieve Substantial Performance by August 1, 2024.
- Revise: D20.1 to read: The Contractor shall achieve Total Performance by September 15, 2024.

PART E – GENERAL REQUIREMENTS

Add: E22. EXPEDITED SHOP DRAWINGS

- E22.1 In order to expedite Shop Drawings with critical timeliness, the Lowest Responsive Bidder, as outlined in B18.1, after receiving written approval from the Contract Administrator, is to arrange for the preparation of Shop Drawings for the following items with critical timelines.
 - a) Electrical items including MCC, VFDs and PLC control panel.
- E22.2 If Award is made to the Lowest Responsive Bidder, no payment for the preparation of Shop Drawings will be made.
- E22.3 If no Contract is awarded, then the City of Winnipeg will pay the requested Bidder up to a maximum of five hundred dollars (\$500.00) for each of the requested submissions noted above, for the preparation and delivery of Shop Drawings. Delivery of the Shop Drawings to the City and payment of the above amounts will constitute full and final consideration of each party to the other, and neither party will have any further liability to the other with respect to this Tender.

NMS SPECIFICATIONS

Section 22 42 01 Piping Specialties and Accessories

Replace: 2.3.5 Acceptable Manufacturers – Zoeller, Bell & Gossett

Section 23 31 13 Metal Duct and Dampers

Add: 2.12 Acceptable Manufacturers – Rushkin, Alumavent, Nailor, TAMCO

Section 23 34 00 HVAC Fans

Add: 2.4.3 Acceptable Manufacturers – Greenheck, Twin City, PennBarry, Loren Cook

Section 23 37 13 Grilles, Registers and Diffusers

Add: 2.1.3 Acceptable Manufacturers – EH Price, Titus, Nailor

Section 23 37 20 Louvers, Intakes and Vents

Add: 2.1.2 Acceptable Manufacturers – Greenheck, Ventex, Nailor

Section 23 81 23.01 Single Split Air Conditioning

Add: 2.3.4 Acceptable Manufacturers – Samsung as a commercial unit only

QUESTIONS AND ANSWERS

Q1: Do you require a Coordination Study as noted in Section 26 28 21 or use the one as indicated in Appendix D?

A1: The Coordination Study in Appendix D is to be used. The breaker trip settings are also in the “Breaker Protection Settings” table on the Single Line Diagram.