



# 167-2023 ADDENDUM 1

## BANNATYNE FLOOD PUMPING STATION – 2023 UPGRADES

### URGENT

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
BID/PROPOSAL**

ISSUED: March 27, 2023  
BY: Brian Cleven, P.Eng.  
TELEPHONE NO. 204 786-8080

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID/PROPOSAL AND SHALL FORM  
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

### PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, April 6, 2023.

### DRAWINGS

Replace: 167-2023\_Drawing\_1-0118F-E0012-001-00 with 167-2023\_Addendum\_1\_Drawing\_1-0118F-E0012-001-01

Replace: 167-2023\_Drawing\_1-0118F-M0003-001-00 with 167-2023\_Addendum\_1\_Drawing\_1-0118F-M0003-001-01

### NMS SPECIFICATIONS

Revise: 22 10 10 Pumps: Add Clause 2.1.4 to read:

Acceptable materials: Bell & Gossett, or approved equal in accordance with B7.

Add: 23 09 33 Electric and Electronic Control Systems for HVAC Clause 2.5:

Cooling Equipment Controls

.1 Product requirements for cooling equipment controls are specified in Section 40 92 00

Revise: 23 33 15 Dampers - Operating: Clause 2.1.11 to read:

Acceptable materials: Tamco 9000, **Alumavent**, **Nailor**, or approved equal in accordance with B7.

Revise: 23 33 15 Dampers - Operating: Clause 2.2.11 to read:

Acceptable materials: Tamco 1000, **Alumavent**, **Nailor**, or approved equal in accordance with B7.

Add: 23 34 00 HVAC Fans and Air Conditioners: Clause 2.2.1.7 to read:

Fan to be direct drive.

- Revise: 23 34 00 HVAC Fans and Air Conditioners: Clause 2.2.2.2 to read:  
Acceptable Materials: Greenheck SQ, **Loren Cook**, or approved equal in accordance with B7. **Equipment must fit within restrictions of space as shown on drawings.**
- Revise: 23 34 00 HVAC Fans and Air Conditioners: Clause 2.3.5 to read:  
Acceptable materials: Bard W150APQ0ZEP c/w RG-10W; **Engineered Air FWA**, or approved equal in accordance with B7.
- Add: 23 34 00 HVAC Fans and Air Conditioners: Clause 2.3.6:  
Controller complete with temperature/humidity sensor. Acceptable materials: Bard LC6000 or approved equal in accordance with B7.
- Revise: 23 37 14 Diffusers and Grills: Clause 2.2.2 to read:  
Acceptable materials: Price 520/D/F/L/A, **Nailor**, or approved equal in accordance with B7.
- Revise: 23 37 14 Clause 2.3.2 to read:  
Acceptable materials: Price 520/Z/D/A/L, **Nailor**, or approved equal in accordance with B7.
- Add: 40 92 00 Automation - Primary Control Devices - Clause 2.7 to read:  
Cooling Equipment Controller  
.1 Temperature controlled by wall mounted thermostat provided by cooling equipment manufacturer