



190-2023 ADDENDUM 1

SUPPLY AND DELIVERY OF ICE PLANT SYSTEM CONTROLS

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: David Firth
BY: March 1, 2023
TELEPHONE NO. 204 451-4098

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

FORM B: PRICES

Replace: 190-2023 Form B: Prices with 190-2023 Addendum 1- Form B: Prices. The following is a summary of changes incorporated in the replacement Bid/Proposal Submission:

Form B(R1): Item 6 description revised

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, March 20, 2023.

PART E – SPECIFICATIONS

Revise: E2.1.6 to read: Item No. 6 – BACnet, Current / Voltage Transducers, CVT, Rogowski, small, 800A, 6ft leads, 3 phase kit, shall be Manufactured by Senva Inc. or Johnson Controls Inc., model no. CVT-F08S-L06-3PH