



478-2023 ADDENDUM 1

HURST REGIONAL PUMPING STATION CHILLER AND CONTROLS UPGRADES

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID/PROPOSAL

ISSUED: August 18, 2023
BY: Claude Courchaine
TELEPHONE NO. 204 928-7415

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID/PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B – BIDDING PROCEDURES

- Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, September 1, 2023.
- Add: B3.8 Further to C3.1, the Contract Administrator or an authorized representative will be available at the Site at 9:00 a.m. on August 24, 2023 to provide Bidders access to the Site.
- Add: B3.9 The Bidder is required to register for the Site investigation by 4:00 p.m. Winnipeg time, August 22, 2023 by contacting the Contract Administrator identified D6.

PART D – SUPPLEMENTAL CONDITIONS

- Revise: D6.1 to read: The Contract Administrator is AECOM Canada Ltd., represented by:
 - Claude Courchaine, P. Eng. (Primary Contact)
 - Mechanical Engineer
 - Telephone No. 204 928-7415
 - Email Address claudio.courchaine@aecom.com
 - Brad Peterson, P. Eng. (Alternative Contact #1)
 - Project Manager
 - Telephone No. 204 801-5894
 - Email Address brad.peterson@aecom.com
 - Connor Fedorchuk, E.I.T. (Alternative Contact #2)
 - Mechanical Engineer-in-Training
 - Telephone No. 204 998-0093
 - Email Address connor.fedorchuk@aecom.com

- Revise: D18.3 to read: The City intends to award this Contract by September 22, 2023.

APPENDICES

- Add: Appendix E – Site Photos

NMS SPECIFICATIONS

Section 23 21 16 HYDRONIC PIPING SPECIALTIES

- Revise: 2.1.8 to read: Acceptable material: Amtrol, Armstrong, Bell & Gossett, Taco, or approved equal in accordance with B7.
- Revise: 2.4.5 to read: Acceptable material: Armstrong, Bell & Gossett, Taco, or approved equal in accordance with B7.
- Revise: 2.7 to read: TRIPLE DUTY VALVE

Section 23 21 23 HYDRONIC PUMPS

- Add: 2.3.10 Acceptable material: Armstrong, Bell & Gossett, Taco or approved equal in accordance with B7.

Section 23 25 00 HVAC WATER TREATMENT

- Revise: 2.3.2.2 to read: 20 micron filter cartridges 500 mm long, 65 mm OD, cotton, tinned ST core. Acceptable Material: Chem-Aqua, Axiom, or approved equal in accordance with B7.
- Revise: 2.3.3.1 to read: Epoxy coated carbon steel construction, 7.5 litre capacity, seals to be suitable for polypropylene service, 2.0 MPa maximum working pressure at 93 degrees Celsius, 89 mm threaded cap, four 3/4 inch NPT ports. Acceptable Material: General Filtration model PF-2-X4-HP, Axiom, or approved equal in accordance with B7.

QUESTIONS AND ANSWERS

Q1: Can Substantial and Total Performance dates be moved to accommodate long lead times for equipment?

A1: D24 of the Tender addresses instances of supply chain disruption schedule delays.