



478-2023 ADDENDUM 2

HURST REGIONAL PUMPING STATION CHILLER AND CONTROLS UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: August 30, 2023
BY: Connor Fedorchuk
TELEPHONE NO. 204 998-0093

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, September 12, 2023.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D18.3 to read: The City intends to award this Contract by October 2, 2023.

APPENDICES

Add: Appendix F – Site Photos (Electrical)

NMS SPECIFICATIONS

Add: Section 01 52 00 - CONSTRUCTION FACILITIES

Section 23 64 16 - CENTRIFUGAL WATER CHILLERS

Delete: 3.3.7:

QUESTIONS AND ANSWERS

Q1: Is the Contractor responsible for demolishing and removing the existing cooling tower and the pad it rests on, and restoring the affected grassed area?

A1: No, this will be completed by the City.

Q2: Is the Contractor responsible for demolishing and removing the existing chiller?

A2: No, this will be completed by the City.

Q3: Is the Contractor responsible for removing the refrigerant from the existing chiller?

A3: No, this will be completed by the City.

Q4: Is the Contractor responsible for draining the glycol from the existing chilled water system and providing storage tanks?

A4: No, this will be completed by the City.

Q5: Is the Contractor responsible for installing City supplied refrigerant?

A5: No, this will be completed under a separate Contract. See deletion from specification Section 23 64 16.

Q6: Is the Contractor responsible for supplying and installing a new glycol solution for the entire new system?

A6: Yes, per specification Section 23 25 00.

Q7: Can temporary scaffolding be set up on the pump floor/grating for the work?

A7: Yes, see also added specification Section 01 52 00. The Contractor may also use the existing overhead crane in the pump station per E8 of the Tender.