



# 524-2023 ADDENDUM 1

## WINNIPEG TRANSIT NORTH GARAGE 2023 STRUCTURAL REPAIRS

### URGENT

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
BID/PROPOSAL**

ISSUED: November 10, 2023  
BY: Paulo Guzzi, Crosier Kilgour  
TELEPHONE NO. 204 943-7501

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID/PROPOSAL AND SHALL FORM  
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

### CLARIFICATIONS

1. Shoring for column repairs to consist of minimum 12 kip shoring posts on each side of column bearing on 4'x4' timber footings at base.
2. An on-site skid steer will be permissible strictly for removal/transportation of materials and may not be stored or remain idle within the parking garage.
3. A site storage area for contractor equipment can be accommodated within an existing storage shed at the west parking lot.
4. The Contractor may store an on-site waste bin immediately next to the garage entrance door or along the first row of parking within the west parking lot.
5. The height of the steel columns identified for repair are approximately 16'-0"±.
6. The Winnipeg Transit North Garage will accommodate access to power/water for The Contractor.
7. The existing slab thickness is approximately 6"±.
8. In accordance with the project specifications, the following units are associated with items 10-13:

10.	Full Depth Slab-on-Grade Concrete Repairs beyond the extents shown on Drawings.	03 92 20	ft <sup>2</sup>	50
11.	Supplemental Reinforcing Steel: 10M and 15M bars	03 30 00	kgs	25
12.	Vertical form and pour repairs of columns (0"-3")	03 93 30	ft <sup>2</sup>	10

13.	Vertical form and pour repairs of columns (3"-6")	03 93 30	ft <sup>2</sup>	10
-----	---	----------	-----------------	----

9. *Form B Item 10: Full Depth Slab-on-Grade Concrete Repairs beyond the extents shown on Drawings* is to apply for all slab-on-grade repairs identified by the Project Administrator at the time of construction beyond the areas shown dimensioned on the drawings.