



## 633-2023 ADDENDUM 2

### ROOF REPLACEMENT - 1501 CHURCH

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
BID/PROPOSAL**

ISSUED: August 30, 2023  
BY: Mike Rothwell  
TELEPHONE NO. 204 451-4096

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID/PROPOSAL AND SHALL FORM  
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

#### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, September 5, 2023.

#### **QUESTIONS AND ANSWERS**

Q1: Question was asked about Drawing A1.5 – Flashing Detail. What is the deck sheathing?

A1: Deck sheathing is to be: minimum 1/2" x 4' x 8': Glass-mat sheathing GP Dens Deck Prime Roof Board.