



866-2023 ADDENDUM 1

PARTIAL ROOF REPLACEMENT – WFPS HEADQUARTERS BUILDING – 2546 MCPHILLIPS

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: November 10, 2023
BY: Mike Rothwell
TELEPHONE NO. 204 451-4096

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART E – SPECIFICATIONS

Revise: E2.3 to read: DRYWALL SHEETING

This shall be 1/2" DensDeck Prime as manufactured by Georgia Pacific or approved equal.
Securock Gypsum Fiber Roof Board 3/8" is accepted as an approved equal.

Revise: E2.11 to read COVER BOARD

This shall be 1/2" DensDeck Prime as manufactured by Georgia Pacific or approved equal.
Securock Gypsum Fiber Roof Board 3/8" is accepted as an approved equal.

DRAWINGS

Replace: 866-2023_Drawing_R1-R0 with 866-2023_Addendum_1 Drawing_R1-R1

866-2023_Drawing_R2-R0 with 866-2023_Addendum_1-Drawing_R2-R1