



## 866-2023 ADDENDUM 3

### PARTIAL ROOF REPLACEMENT – WFPS HEADQUARTERS BUILDING – 2546 MCPHILLIPS

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
BID/PROPOSAL**

ISSUED: November 17, 2023  
BY: Mike Rothwell  
TELEPHONE NO. 204 451-4096

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID/PROPOSAL AND SHALL FORM  
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

#### **PART E – SPECIFICATIONS**

Add: E4.59 Radio antenna tower and all related hardware is to be removed from roof A1.5 as part of the Tender.

#### **DRAWINGS**

Replace: 866-2023\_Addendum\_1-Drawing\_R1-R1 with 866-2023\_Addendum\_3-Drawing\_R1-R2

#### **QUESTIONS AND ANSWERS**

Q1: What is the status of the ladder?

A1: The ladder was removed from Tender. It had been removed in the Specs, but not in Drawing R1. The ladder will be left in place and replaced at a later date. City of Winnipeg Staff will modify top of ladder to not interfere with parapet work.



^