



867-2023 ADDENDUM 1

PARTIAL ROOF REPLACEMENT – 1539 WAVERLEY

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: November 14, 2023
BY: Mike Rothwell
TELEPHONE NO. 204 451-4096

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART E – SPECIFICATIONS

Revise: E2.3 to read: DRYWALL SHEETING

This shall be ½” DensDeck Prime as manufactured by Georgia Pacific, Securock Gypsum Fiber Roof Board or approved equal.

Revise: E2.9 to read: COVER BOARD

This shall be 1/2” DensDeck Prime as manufactured by Georgia Pacific, Securock Gypsum Fiber Roof Board or approved equal.

Revise: E4.1 to read: The Roofing Contractor’s Association of Manitoba 5-year warranty or an approved equal is to be provided.

QUESTIONS AND ANSWERS

Q1: Where is Contractor to set up?

A1: Setup location is to area marked in red in image attached.

